

بن غاطي BINGHATTI	<h2 style="margin: 0;">Documents Submittal Form</h2>	SILVER STONE <small>ENGINEERING CONSULTANTS</small>	
------------------------------------	--	---	--

Project Name:	ONE DOWNTOWN BY BINGHATTI (SKYBLADE)		
Project Proposed:	4B+G+3P+61F+Roof	Client:	BINGHATTI Properties Investment LTD.
Project Location:	Burj Khalifa District	Engineering Consultant:	Silverstone Eng'g Consultants
Project Plot No.:	3450398	Main Contractor:	Granada Europe Const. Co.

DS Reference No.:	BBY006-GEC-DCS-ST-GE-0054	DS Date:	20-June-2025	DS Rev.:	01
<i>Engineering Consultant has fourteen (14) working days to respond after the document has been submitted.</i>					

DS SCOPE OF WORK				
<input type="checkbox"/> ARCH	<input checked="" type="checkbox"/> STR	<input type="checkbox"/> MEP	<input type="checkbox"/> ID/ED	<input type="checkbox"/> AI

DOCUMENT SUBMITTALS INFORMATION:				
Doc. Ref. No.	Description	Pages	Discipline	Remarks
	Document submittal for Sub structure Retaining wall Mix design	1	STR	UNIMIX

DOCUMENT TYPE: DISCIPLINE (TICK APPROPRIATE SCOPE OF WORK)			
<input type="checkbox"/> Method Statement / TDS	<input type="checkbox"/> Warranties	<input type="checkbox"/> Reports	<input checked="" type="checkbox"/> Other:

MAIN CONTRACTOR CONFIRMATION			
<input checked="" type="checkbox"/> Civil Engineer	<input checked="" type="checkbox"/> Technical Manager	<input checked="" type="checkbox"/> Project Director	
Eng. Jithu.S	Eng. Murad Nasrawin	Eng. Mohamed Elaraby	
Signature:	Date: 12-06-2025	Signature:	Date: 12-06-2025
<i>The Contractor strictly confirms herewith that the DS has been studied carefully & coordinated precisely as per the approval of all drawings from the authorities and approved specifications from the engineering consultant, enclosed with engineering comments from other parties (if required).</i>			





This submittal is intended to:			
<input checked="" type="checkbox"/> Review/ Approval	<input type="checkbox"/> Information/Records	<input type="checkbox"/> As per request	<input type="checkbox"/> Other, Specify Below







QA/QC ENGINEERS COMMENTS AND ACKNOWLEDGMENT	
-Corrosion inhibitor has been added as per consultant previous comment (Complied). Approval is subjected to satisfactory test results for Trail mix. To comply with related authorities regulation and requirements. Final approval is subjected to SS approval.	
<input checked="" type="checkbox"/> CIVIL	<input type="checkbox"/> MEP







ENGINEERING COSULTANT COMMENTS AND APPROVAL STATUS							
<input type="checkbox"/> Approved (A)		<input checked="" type="checkbox"/> Approved as Noted (B)		<input type="checkbox"/> Re- Submit (C)			
- Trial mix to be conducted for proposed concrete mix in accordance with project requirements. Approval is subject to satisfactory Trial mix results. - Cylinder samples to be taken for testing of compressive strength for concrete grade C70 and higher. - Detailed trial mix report shall be provided for Engineer's review and approval including properties of fresh concrete (slump, temperature, density, air content, bleeding, etc.), durability results, compressive strength results, modulus of elasticity, etc as per the project specifications. - Provide TDS for the proposed corrosion inhibitor MCI 2005. - Provide heat of hydration calculations for the proposed concrete mix.							
<input type="checkbox"/> ARCH	<input type="checkbox"/> STR	<input type="checkbox"/> MEP	<input type="checkbox"/> ID/ED	<input type="checkbox"/> AI			
		Yosri Abdelmageed					
Signature:	Date:	Signature:	Date:	Signature:	Date:		
<div style="display: flex; justify-content: space-between;"> <div> - Confirmation/compatibility letters from crystalline waterproofing admixture manufacturer/supplier and corrosion inhibitor manufacturer to be provided confirming the compatibility of their material with all other ingredients and admixtures. - Chloride migration coefficient (NT Build 492) shall not exceed $2.0 \times 10^{-12} \text{ m}^2/\text{s}$. Samples to be taken during trial mix. - Contractor and supplier are responsible to take the necessary measures to control concrete temperature within acceptable limits. - Frequency of compressive strength and durability testing shall comply with approved drawings and project specifications. - Contractor to provide another proposal for Retaining wall concrete mix design with concrete grade C56/70 with heat of hydration calculations. </div> <div style="border: 1px solid black; padding: 5px; width: 200px;"> <div style="background-color: black; color: white; padding: 2px; text-align: center;">(B) Approved As Noted</div> <div style="font-size: 0.8em;"> Submittal was reviewed for design conformity and general performance to contract documents only. The Contractor is responsible for confirming and correlating Dimension at job site for tolerance, clearance, quantities, fabrication processes and techniques of construction, coordination of his works with other trades and full compliance with contract documents. </div> <div style="font-size: 0.7em;"> Reviewed By : Yosri Abdelmageed Date : SS Head of Supervision: Eng. Ahmad Odeh </div> </div> </div>							

- Notes: This submittal has been reviewed in absence of relevant authority approved drawings. Contractor shall revisit and validate this document upon receiving the approved drawings, and subsequently demonstrate the changes. Contractor can proceed with the trial mix under their own responsibility.

Client	Consultant	Main Contractor			
PREQUALIFICATION SUBMITTAL					
PROJECT : PROPOSED RESIDENTIAL BUILDING (G+P+10+ROOF) PNO & LOCATION : DG-CTLZ-001 AT AL JABAL ALI FIRST DUBAI CLIENT : M/S . MASHRIQ ICON HOLDINGS LIMITED CONSULTANT : EMSQUARE ENGINEERING CONSULTANTS					
No: CJ/173/PQ/CVL/13 Rev/0 Date: 02/05/2025					
WE ARE SUBMITTING HERewith DOCUMENTS FOR REVIEW & APPROVAL					
Technical Submission	Architecture <input type="checkbox"/>	Structure <input type="checkbox"/>	Electrical (HV / LV) <input type="checkbox"/>	Plumbing & Drainage <input type="checkbox"/>	
	HVAC <input type="checkbox"/>	FF. FA & EL <input type="checkbox"/>	Specialist Works <input type="checkbox"/>	Specialist Works <input type="checkbox"/>	
Drawing Ref: BOQ & Specs Ref: Prequalification Description: Supplier of Waterproofing Admixture in Substructure Concrete (Material - Cormix H20 Waterstop) Prequalification Details: Galaxy Specialised Waterproofing Co L.L.C Enclosures: Attached					
Submitted By: Main Contractor:		Conformity By: MEP Contractor:		Received By: Consultant:	
CONSULTANT COMMENTS: ① Submit M/S Galaxy Specialized Water Proofing Co., L.L.C NO OBJECTION. ② Submit material Submittal for Consultant Review / Approval ③ Arrange Trial Mix and Third Party Trial Mix Reports to be done.					
CLIENT COMMENTS: 					
Consultant Recommendation	Approved	Approved With Comments	Revise & Re-Submit	Rejected	For Discussion
Client Recommendation	Approved	Approved With Comments	Revise & Re-Submit	Rejected	For Discussion
Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings, specifications & authority norms & regulations. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all design details & specifications, authority norms & regulations, method statement, shop-drawings & design approvals, manufacturer recommendations, fabrication process and techniques of construction along with coordinating work with other trades, and executing the works in a safe and satisfactory manner.					
FOR EMSQUARE ENGINEERING CONSULTANT			FOR (Client *****)		
QC ENGINEER - CIVIL Sign & Date:		QC ENGINEER - MEP Sign & Date:		PROJECT ENGINEER - CIVIL Sign & Date:	
RESIDENT ENGINEER - CIVIL Sign & Date:		RESIDENT ENGINEER - MEP Sign & Date:		PROJECT MANAGER - CIVIL Sign & Date:	
Additional Comments / Information:					

									
Client		Consultant		Main Contractor					
DOCUMENT SUBMITTAL									
PROJECT :	PROPOSED RESIDENTIAL BUILDING (G+P+10+ROOF)				No: C/173/CVL/DS/08 Rev 0				
PNO & LOCATION :	DG-CTLZ-001 AT JABAL ALI FIRST DUBAI				Date: 26/03/2025				
CLIENT :	M/S. MASHRIQ ICON HOLDINGS LIMITED								
CONSULTANT :	EMSQUARE ENGINEERING CONSULTANTS								
WE ARE SUBMITTING HERewith DOCUMENTS FOR REVIEW & APPROVAL									
Technical Submission	Architecture	<input type="checkbox"/>	Structure	<input checked="" type="checkbox"/>	Electrical (HV / LV)	<input type="checkbox"/>	Plumbing & Drainage	<input type="checkbox"/>	
	HVAC	<input type="checkbox"/>	FF, FA & EL	<input type="checkbox"/>	Specialist Works	<input type="checkbox"/>	Specialist Works	<input type="checkbox"/>	
Drawing Ref: NIL									
BOQ & Specs Ref: NIL									
Document Description: Readymix Concrete Mix Design									
C20/20 (64%OPC+36%GGBS) BLINDING C20/10 (64%OPC+36%GGBS) SCREED C50/20 (35%OPC+60%GGBS+5%MS) SUB STRUCTURE C50/20 (35%OPC+60%GGBS+5%MS+WP240) SUB STRUCTURE (WATER TANK, PUMP ROOM) C50/20 (64%OPC+36%GGBS) SUPER STRUCTURE (SLAB, BEAM) C60/20 (60%OPC+35%GGBS+5%MS) SUPER STRUCTURE (COLUMN, WALL)									
Document Details: QUICK MIX BETON READY MIX MANUFACTURING L.L.C									
Enclosures: ATTACHED MIX DESIGN FROM QUICK MIX BETON READY MIX MANUFACTURING LLC									
Submitted By: Main Contractor:				Conformity By: MEP Contractor:		Conformity By: Specialist Contractor:		Received By: Consultant	
CONSULTANT COMMENTS:									
<p>① Ready Mix Concrete Mix Design Shall proceed for TRIAL Mix</p> <p>as per Approved mix design for Approved drawings. and arrange and inform date & time of Trial mix</p>									
CLIENT COMMENTS:									
Consultant Recommendation		Approved	Approved With Comments	Revise & Re-Submit	Rejected	For Discussion			
Client Recommendation		Approved	Approved With Comments	Revise & Re-Submit	Rejected	For Discussion			
Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings, specifications & authority norms & regulations. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all design details & specifications, authority norms & regulations, method statement, shop-drawings & design approvals, manufacturer recommendations, fabrication process and techniques of construction along with coordinating work with other trades, and executing the works in a safe and satisfactory manner.									
FOR EMSQUARE ENGINEERING CONSULTANT				FOR (Client *****)					
QC ENGINEER - CIVIL Sign & Date:		QC ENGINEER - MEP Sign & Date:		PROJECT ENGINEER - MEP Sign & Date:		PROJECT ENGINEER - CIVIL Sign & Date:			
RESIDENT ENGINEER - CIVIL Sign & Date:		RESIDENT ENGINEER - MEP Sign & Date:		PROJECT MANAGER - MEP Sign & Date:		PROJECT MANAGER - CIVIL Sign & Date:			
Additional Comments / Information:									

 <p>انوفيتيف للاستشارات استشاريون في العمارة والهندسة INNOVATIVE CONSULTANTS CONSULTING ARCHITECTS & ENGINEERS Tel: +974 2539179 E-mail: ecor@innovative.ae PO BOX 7835</p>	<p>"PROPOSED COMMERCIAL & RESIDENTIAL BUILDING (G+2P+14TYP+R)" For: MR. ALI ABDULLA MOHAMMAD AL SHIRAWI Plot No.: (326-1501), Al Jadaf, Dubai, U.A.E."</p>	 <p>OLDEN WING CONTRACTING LLC</p>
DOCUMENTS APPROVAL SUBMITTAL		IC-2024-02-DS-07
<p>To: M/s. INNOVATIVE Consultants:</p> <p>Please find attached the following Material Submittal for your approval/comments:</p>		
<p>Discipline:</p> <div style="display: flex; justify-content: space-between;"> <div> <input checked="" type="checkbox"/> Civil/Structural <input type="checkbox"/> Mechanical </div> <div> <input type="checkbox"/> Architectural <input type="checkbox"/> Plumbing </div> <div> <input type="checkbox"/> Electrical <input type="checkbox"/> Others </div> </div>		
Material Details:		List of Enclosures:
Item Description	Method of Statement for Cormix H2O Stop Liquid Admixture System	<input type="checkbox"/> Vendor's Technical Literature
Specs Reference		<input type="checkbox"/> Compliance Statement
BOQ Reference		<input type="checkbox"/> Comparison Sheets
Drg. Reference		<input type="checkbox"/> Previous Test Results
Material Specified		<input type="checkbox"/> Copy of the Related Specs & Other Contract Documents
Material Proposed		<input checked="" type="checkbox"/> Sample Board
Sub Contractor	Galaxy Specialised Waterproofing Co. LLC. P.O Box 47425, Tel NO. 3474711, Dubai. U.A.E.	<input type="checkbox"/> List of Projects Done <input checked="" type="checkbox"/> Others (Material Submittal)
		
<p>Submitted by: Eng. Mohd. Irfan</p>		<p>Signature:  Date: 27.01.2025</p>
<p>INNOVATIVE CONSULTANTS COMMENTS:</p> <div style="display: flex; align-items: center;"> <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Not Approved, Resubmit </div>		
<p>Comments:</p> <ul style="list-style-type: none"> • No Objection for the method statement subject to satisfactory performance at site • Main Contractor and M/s Galaxy to coordinate each step to ensure compliance with the method statement. • Main Contractor to ensure obtaining clearance from M/s Galaxy prior to concrete of any substructure element. 		
<p>Checked by: </p>		<p>Signature:  Date: 30/01/2025</p>
<p>Confirmed by:</p>		<p>Signature:</p>
<p><small>Note: INNOVATIVE Comments shall not be considered as a reason of claim of any type unless it is issued via E.I. The contractor should seek an E.I. if he considers that INNOVATIVE comments contain financial or time impact.</small></p>		
<p>• Main Contractor to ensure documenting each step with photos stamped with date and time and raised inspection for Engineer approval of every step.</p>		

 <p>انوفيتيف للاستشارات استشاريون في العمارة والهندسة INNOVATIVE CONSULTANTS CONSULTING ARCHITECTS & ENGINEERS Tel : 9714 2502173 / E-mail : econ@innovae / PO BOX 7855</p>	<p>"PROPOSED COMMERCIAL & RESIDENTIAL BUILDING (G+2P+14TYP+R) For: MR. ALI ABDULLA MOHAMMAD AL SHIRAWI Plot No.: (326-1500), Al Jadaf, Dubai, U.A.E."</p>	 <p>الذراع الخفيف للمقاولات ش.م.م. GOLDEN WING CONTRACTING LLC</p>
DOCUMENTS APPROVAL SUBMITTAL IC-2024-01-MS- 23		
<p>To: M/s. INNOVATIVE Consultants:</p> <p>Please find attached the following Material Submittal for your approval/comments:</p>		
<p>Discipline: <input checked="" type="checkbox"/> Civil/Structural <input type="checkbox"/> Architectural <input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Plumbing <input type="checkbox"/> Others</p>		
Material Details:		List of Enclosures:
Item Description	Cormix H2O Stop Liquid Admixture System	<input type="checkbox"/> Vendor's Technical Literature
Specs Reference		<input type="checkbox"/> Compliance Statement
BOQ Reference		<input type="checkbox"/> Comparison Sheets
Drg. Reference		<input type="checkbox"/> Previous Test Results
Material Specified		<input type="checkbox"/> Copy of the Related Specs & Other Contract Documents
Material Proposed	Cormix H2O Stop Liquid Admixture System	<input type="checkbox"/> Sample Board
Sub Contractor	Galaxy Specialised Waterproofing Co. LLC. P.O Box 47425, Tel No. 04-3474711, Dubai, U.A.E	<input type="checkbox"/> List of Projects Done
		<input checked="" type="checkbox"/> Others (Method of Statement)
		
<p>Submitted by: Eng. Mohd. Irfan Signature:  Date: 24.01.2025</p>		
<p>INNOVATIVE CONSULTANTS COMMENTS:</p> <p><input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Not Approved, Resubmit</p>		
<p>Comments:</p> <p>• Trial Mix to be carried on for Cormix H2O stop admixture and cube results for compressive strength and durability to be submitted for Engineer approval prior to proceed with using the admixture.</p> <p>• Coremix H2O stop admixture must be mentioned in the concrete delivery note. If not mentioned, truck will be rejected.</p>		
<p>Checked by:  Signature:  Date: 24/01/25</p>		
<p>Confirmed by: Signature: Date:</p>		
<p><small>Note: INNOVATIVE Comments shall not be considered as a reason of claim of any type unless it is issued via E.I. The contractor should seek an E.I. if he considers that INNOVATIVE comments contain financial or time impact.</small></p>		

Received
25-01-25

- Subject to satisfactory performance at site.
- Follow manufacture recommendations for usage, dosage, storage etc.

Ref. #: ECO-069/ENAWT 2/LTR-3DCont/2025-08

Date: 23th January 2025

To : M/S 3D CONSTRUCTION L.L.C

Tel No. 04-2990922

Email Address: 3dconstructionllc@gmail.com

**PROJECT : ENAWT TOWER-2 (Comm. & Res. Bldg G.+4P. +18F. +R.)
On Plot No. 6817732 (DM) / JVC17TCP001A (Nakheel)
at Al Barsha South 4th-Dubai – U.A.E**

CLIENT : M/s. ENAWT REAL ESTATEDEVELOPMENT LLC

SUBJECT : Foundation water proofing (CORMIXH2O STOP)

Dear Sir,

With Reference to above mentioned project, subject and please be informed that your proposal is approved from client and consultant subject to the following :

- 1- Water tank Dosages of Galaxy product **CORMIXH2O** not less than 6kg/m³ with 2 layer thickness 4mm membrane and protection board one layer thickness 3mm for vertical and 50mm screed for horizontal from external and GRP liner coated 6mm from inside.
- 2- Piles caps and strip beams Dosages of Galaxy product **CORMIXH2O** not less than 5kg/m³ with rubberized bitumen 2coat.
- 3- 25 years warranty certificate from Date of handing over project.
- 4- Dosages of cormix H2O stop to be submitting with concrete mix Design for approval.
- 5- Only Galaxy specialised waterproofing CO. L.L.C. to supervise and carry out of admixture Dosage during the pouring concrete.
- 6- Full responsibility of main contractor and sub contractor to comply with project specification and Authorities requirement.
- 7- Details and shop drawing to be submitted to consultant for final approval.

This is for your information and necessary action.

Sincerely yours,

ECO ENGINEERS CONSULTANTS OFFICE

Engr. Garelnabi Rashed
CEO





MALABAR
GOLD & DIAMONDS



PROJECT NO. P745

PROJECT DETAILS : B+G+2 Residential Villa on Plot 6181340 at Nadd Al Shiba First

MATERIAL SUBMITTAL

Date submittal prepared:	21.01.2025	Submittal Ref:	AZT-P1234-MS-C-0025	Rev. No. 005
Material description :	CONCRETE MIX DESIGN	Vendor List	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Specs. / BOQ / Drwg. Reference		Reason for Alternative		
Sub-Contractor:		Type of material	<input type="checkbox"/> Arch/ID <input type="checkbox"/> Str <input type="checkbox"/> MEP	
Address:				
Material description:	CONCRETE MIX DESIGN	Catalogue Ref:		
Manufacturer:	AL AZZANI READY MIX LLC	Supplier:	AL AZZANI READY MIX LLC	
Brand:				
Address:		Address:		
Area of usage :		Production period:	Weeks	
Spec. Ref:		Delivery Ex-works:	Weeks	
BOQ Ref:		Total Delivery time:	Weeks	
Date Material required at site as per BL:		Expected date of delivery to site:		
Delivery method:				
Overland	Sea Freight	<input type="checkbox"/> Air Freight	<input type="checkbox"/> Other	

Contractor's comments:

If alternate Material submitted, attach full comparison to that specified.

Attachments/Enclosures:

- ☐ Catalogues
☒ Vendor's Technical Literature
☐ Drawings
☒ Compliance Statement
☐ Samples
☒ Previous Test Results
☐ Other (please specify)
☒ Copy of the Related Specs.

Contractor's Authorized Signature:

Date: 21.01.2025

Engineer's Comments:

Product Discussed with:

1. For foundation, Cement containing at least 3.5% C3A but not more than 9% C3A is recommended as per soil report.
2. Final approval is subject to the satisfactory test reports for trail mix.
3. Durability of concrete shall be ensured as per project specification by taking samples from site.
4. No objection for the Concrete Mix Design subject to the compliance with DDA stamped drawings and project specification.
5. DCL certification of batching plant, trucks and other certification shall be valid during the concreting. Main Contractor to verify the same before placing order.

- ☐ Manufacturer
☐ Authorized Distributor
☐ Supplier
☐ Trade Licence
☐ Manufacturer's letter of supplier
☐ Manufacturer's product distribution authorization
☐ letter of application

Site Team

Status			
<input type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved with comments	<input type="checkbox"/> Not approved. Revise & submit	<input type="checkbox"/> Rejected as comments
Project Manager: Midhun	Engineer:		
Date: 23-Jan-2025	Date:		

Design Team (To be reviewed by the designers associated with the material)

Status

- ☐ Sample received & checked
☐ Technical data sheet reviewed
☐ Approved
☐ Approved with comments
☐ Not approved. Revise & submit
☐ Rejected as comments

Architect:	Structural Engineer:	Mechanical Engineer:	Electrical Engineer:
Date:	Date:	Date:	Date:

QA/QC

Status

- ☐ Approved
☐ Approved with comments
☐ Not approved. Revise & submit
☐ Rejected as comments

QA/QC Engineer:

Date:



Eng. Adnan Saffarini Office
Architects & Engineering Consultants

Page 1 of 1

Doc Ref.: EAS-MST

Form sheet Title:

Material Submittal Transmittal

TS No.

EAS-DEE-MST-CIV-0032

Rev.

00

Date

Thursday, 16 January 2025



New Submittal



Re-Submittal

Project Title

RASHID & LATIFA SCHOOL-GIRL'S

Client

M/s. Engineering Office

Plot No.

Consultant

M/s Eng. Adnan Saffarini Office (EAS)

Contractor

DARWISH ENGINEERING EMIRATES

Sub-contractor

M/s Tremix

Building / Area

Trade

Subject of Submittal

Material submittal for Ready-mix Concrete for Water tank (Concrete with crystalline waterproof admixture)

Attachments

☐ Pre-Qualification of Subcontractor

☐ Method Statements

☐ Guarantee

☐ Test Results

☐ Certificate

☒ Others

Requested By Contractor

Name: **Eng. Esam Radwan - Project Manager (DEE)**

Signature: _____

Date: / /

Time: :

Received by Consultant

Name: **Eng. Ehab Yasin - Resident Engineer (EAS)**

Signature: _____

Date: 16/1/25

Time: 3:pm

Consultant's Comments (Project Manager / Resident Engineer)

Propose a product that in definition is "hydrophilic" and attach a letter from supplier with recommended dosage for This project. (This is for waterproof admix), and for inhibitors, its approved.


Approval Status

☐ Approved

☐ Approved As noted

☒ Re-Submit As noted

☐ Rejected



Name of Consultant's Representative: **Eng. Ehab Yasin - Resident Engineer (EAS)**

Signature: _____

Date: / /

Time: :

NOTE:

- For Re-Submittal, copy of previous commented submittal should be attached.
- Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the contract requirement and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.

MATERIAL APPROVAL SUBMITTAL

IC-2024-03-MA- 20

To: M/s. INNOVATIVE Consultants:

Please find attached the following Material Submittal for your approval/comments:

Discipline: ☒ Civil/Structural ☐ Architectural ☐ Electrical
☐ Mechanical ☐ Plumbing ☐ Others

Material Details:

List of Enclosures:

Item Description	Waterproofing Work	<input type="checkbox"/> Vendor's Technical Literature
Specs Reference		<input type="checkbox"/> Compliance Statement
BOQ Reference		<input type="checkbox"/> Comparison Sheets
Drg. Reference		<input type="checkbox"/> Previous Test Results
Material Specified		<input type="checkbox"/> Copy of the Related Specs & Other Contract Documents
Material Proposed	Waterproofing Work - Cormix H2O Stop Liquid Admixture System	<input type="checkbox"/> Samples
Manufacturer/ Local Supplier	galaxy Specialised Waterproofing Co. LLC ,P.O Box 47425, Dhabi U.A.E, Tel NO. 04-3474711	<input type="checkbox"/> List of Projects Done
		<input type="checkbox"/> Others

Submitted by: Eng. Danish Parwez

Signature: 

Date: 18.09.2024

INNOVATIVE CONSULTANTS COMMENTS:

- ☐ Approved
☒ Approved with Comments
☐ Not Approved, Resubmit

Comments:

Trial mix to be carried on for Cormix H2O stop admixture and cube results for compressive strength and durability to be submitted for Engineer approval prior to proceed with using the admixture.
 • Cormix H2O stop admixture must be mentioned in the concrete delivery note. IF not mentioned, truck will be rejected.

Checked by: 

Signature: 

Date: 23/09/2024

Confirmed by:

Signature:

Date:

Note:

INNOVATIVE Comments shall not be considered as a reason of claim of any type unless it is issued via E.I.
 The contractor should seek an E.I. if he considers that INNOVATIVE comments contain financial or time impact.

- Subject to Satisfactory Performance at site.
- Follow manufacture recommendations for usage, dosage, storage etc.

Employer		Consultant		Contractor	 المبنى العصري للمقاولات Tel.: 04-234445 , Fax: 04-2344554
----------	---	------------	---	------------	---

DOCUMENTS APPROVAL REQUEST

No. AXM-DEC-MBC-DAR-005 Rev:01
 Date: 06/Sep/24

Project Information:

Project:	2B+G+5+R COMMERCIAL-RESIDENTIAL BUILDING, Dubai - UAE
Employer:	M/ s. AXIOM INVESTMENT LIMITED
Consultant:	M/s. Datum Engineering Consultants
Contractor:	M/s. Modern Building Contracting L.L.C.

1-Subject & Description : PRE-QUALIFICATION FOR GALAXY SPECIALISED WATERPROOFING LLC.

2- Type of Submittal :

☒ Prequalification
 ☐ Calculation
 ☐ Method statement
 ☐ Schedule
 ☐ Quotation
 ☐ Other

3- Submittal Details:

1. PRE-QUALIFICATION FOR GALAXY SPECIALISED WATERPROOFING LLC. (FOR SUB STRUCTURE WORKS)
- 2.
- 3.
- 4.
- 5.
- 6.
- 7.

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Contractor:

Received by Consultant:

Date:

Date:

4-Consultant's Response

-approved subject to providing the following within (3) days :

(1) Draft Guarantee letter by :
 a) Manufacture b) applicator c) main contractor

2) provide a detailed supervision plan, testing & monitoring and inspection methodology to ensure quality effectiveness of system.

3) site visits to completed projects using same specs for at least (5) years.

☐ Approved
 ☒ Approved as noted
 ☐ Resubmit as noted
 ☐ Rejected

Consultant:

Received by Contractor:

Date:

Date:

Approval shall not relieve Contractor of any of his obligations under the Contract or constitute authorization of any change to Contract Documents or variation to the works. Contractor is responsible for dimensions, quantities and coordination with other trades.

Project Title	: Residence Villa, B+G+1+R	Ref. No.: PJ185/PJR36/TS/018	Rev.: 00
Project Location	: Villa R36, Al Thanyah Fourth, Emirates Hills	Date of Issue	: 04/09/2024
Consultant	: Creative Line Engineering Consultants	Project Manager:	Ahmad Ali
Main Contractor	: Elemech Interiors & Contracting	Sub-contractor	: N/A
Specification Reference:	N/A	Discipline	: As described below


Discipline:	Architectural <input checked="" type="checkbox"/>	Civil / Structural <input checked="" type="checkbox"/>	MEP <input type="checkbox"/>	Others <input type="checkbox"/>
--------------------	---	--	------------------------------	---------------------------------

Subject of Submittal:	PQ for Waterproofing Supplier for Substructure Waterproofing (Supplier –Galaxy Specialized Waterproofing Co. LLC.)
------------------------------	--

Enclosure:	<input type="checkbox"/> Pre-Qualification of Subcontractor	<input type="checkbox"/> Method Statement	<input type="checkbox"/> Guarantee	<input type="checkbox"/> Certificate
	<input type="checkbox"/> Project Quality Plan / Procedure	<input type="checkbox"/> Calculation Notes	<input type="checkbox"/> Test Results	<input type="checkbox"/> Others

Item No.	Item Description	No. of Copies	Remarks
1	Pre-Qualification for Waterproofing Supplier for Substructure	1	

Contractor Authorized Signature:		Date: 04/09/2024
---	---	-------------------------

Consultant Comments:	Approval Status:
1-NO OBJECTION TO PROCEED WITH GALAXY SUBJECTED TO -PROVIDE METHOD OF STATEMENT	<input type="checkbox"/> A- Approved Work May Proceed
2-DOCUMENTS SENT BY THE CONTRACTOR FOR PQ UNDER HIS RESPONSIBILITY	<input checked="" type="checkbox"/> B- Approved as noted Work May Proceed subject to incorporation of comments indicated
	<input type="checkbox"/> C- Reject & Resubmit Revise and Resubmit Work may not Proceed
Consultant Authorized - Name /Signature:	
	Date: 4-9-2024

Client's No Objection Required: (Yes / No)(*)	
Clients Comments:	Review Status:
	<input type="checkbox"/> No Objection
	<input type="checkbox"/> Accepted with comments
	<input type="checkbox"/> Not Accepted
Client Authorized Signature:	Date:

(*) Note:

The above client's review and comments do not in any way absolve the contractor's responsibility of fulfilling the contractual obligation and consultant's responsibility of fulfilling the design & supervision liability requirements.

RIDGE

ENGINEERING
CONSULTANTS

MATERIAL SUBMITTAL MSUB

الجناب الذهبي للمقاولات
GOLDEN WING
CONTRACTING LLC

Reference No.:	014	Date:	20/08/2024
Project Description :	Residential Townhouse – 15 Nos Villa (B+G+2+R)		
Client's Name :	Westar Properties LLC		
Plot No.	JVC14OFRP004		
Location :	Jumeirah Village Circle, Dubai, U.A.E		
Consultant :	Ridge Engineering Consultants		
Contractor :	Golden Wing Contracting LLC		
FROM:	TO:		
Description of Material:			
Mix Design for Sub Structure Raft Slab & Isolated Footings With WP Admixture			<input type="checkbox"/> As per Specification <input type="checkbox"/> Alternative
Attachments:		Discipline:	
<input type="checkbox"/> Samples	<input type="checkbox"/> Original Brochure	<input type="checkbox"/> Civil / Structural	<input type="checkbox"/> Mechanical
<input type="checkbox"/> Drawings / Sketches	<input type="checkbox"/> Specification	<input type="checkbox"/> Architectural	<input type="checkbox"/> SAS
<input type="checkbox"/> Others:		<input type="checkbox"/> Others:	<input type="checkbox"/> ELV / IT <input type="checkbox"/> Electrical
References:			
Drawing Ref. No.:			
Specification No.:			
BOQ Ref. No.:			
International Standards:			
Note: Attach all relevant technical literature marked to identify relevant descriptions, current test certificate, samples, etc. Attach a certificate stating compliance with Contract requirements. Highlight any element of contractual non-compliance in this submittal.			
Manufacturer / Supplier			
Company Name:	Al Azzani Ready Mix LLC	Locally Manufactured:	
Country of Origin:		AGCC Manufactured:	
Authorized Local Agent:	Al Azzani Ready Mix LLC	Production Period:	
Total Delivery Time:	(No. of Days)	Delivery Ex-Works:	
Date Required on Site:		Expected Date of Delivery on Site:	
CONTRACTOR'S REPRESENTATIVE			
Name:	Eng. Mohd. Irfan	Signature:	Date: 20.08.2024
Engineer Comment:			
No objection to proceed subject to incorporation of comments indicated. ② other mix design to be submitted.			
Signed by:		Engineer's Representative	
CODE:	<input type="checkbox"/> 1 – Work may proceed. <input checked="" type="checkbox"/> 2 – Work may proceed subject to incorporation of comments indicated. <input type="checkbox"/> 3 – Revise & resubmit. Work may not proceed.	Acknowledgment Receipt RIDGE ENGINEERING PROJECTS	
Owner's Comments :			
Approval Status			
<input type="checkbox"/> – Approved <input type="checkbox"/> – Not Approved			
CC:	Owner		


2 AUG 2024
RECEIVED



RIDGE/SUP-MSUB-025 Rev 00
Issue date: 12/03/2019

 <p>MONARCH DESIGNS</p>	<p>The Engineer</p> <p>MONARCH DESIGNS ENGINEERING CONSULTANT</p>	 <p>AL ISHRAK CONTRACTING CO. LLC</p>	<p>The Contractor</p> <p>AL ISHRAK CONTRACTING CO. LLC</p>
	<p>Project: <i>B+G+4+R Villa on Plot No. JVT04KMRA008, JVT, Dubai - UAE for Mr. Aamir Shafi Akram</i></p>		

<p>From: <i>Al Ishrak Cont. Co. LLC</i></p>	<p>To: <i>Monarch Consultant</i></p>
--	---

<p align="center">Material Submittal</p>		<p>Ref. No. : <i>MS / 224 /MS/01- Rev.00</i></p>
		<p>Date : <i>14/08/2024</i></p>
<p>Originator of Submittal :</p>		<p>Required By : <i>15/08/2024</i></p>
<p>Material Division / Section :</p>	<i>Civil</i>	<p align="center">List of Enclosures</p> <p align="center">(Tick the related Box)</p> <p><input checked="" type="checkbox"/> Vendor's Technical Literature</p> <p><input type="checkbox"/> Compliance Statement</p> <p><input type="checkbox"/> Test Results</p> <p><input type="checkbox"/> Copy of Related Specs.</p> <p><input type="checkbox"/> Samples</p> <p><input type="checkbox"/> List of Previous Projects done</p> <p><input type="checkbox"/> Others (Specify)</p>
<p>Specs./BOQ/Drg. Ref. :</p>		
<p>Material Specified :</p>	<i>Crystalline waterproofing admixture supply</i>	
<p>Material Proposed :</p>	<i>Cormix H2O Stop Liquid</i>	
<p>Manufacturer / Local Supplier :</p>	<i>Galaxy Specialised Waterproofing Co . LLC</i>	
<p>Reason for Alternative :</p>	<i>N/A</i>	
<p>Description :</p> <p><i>Material Submittal for the Crystalline waterproofing admixture supply</i></p>		
<p>Contractor's PM : Engr. Ebrahim Signature & Date : <i>14/08/2024</i></p> 		<p>Received By Consult : Signature & Date</p>

Contractor's Statement : We certify that the material(s) submitted herewith has/have been reviewed in detail and in compliance with the Contract drawings and specifications except as otherwise stated here above.

Review Status		
<input type="checkbox"/> A. Approved	<input checked="" type="checkbox"/> B. Approved As Noted	<input type="checkbox"/> C. Approved As Noted, Resubmit
<input type="checkbox"/> D. Not Approved, Resubmit	<input type="checkbox"/> E. Returned Unchecked	<input type="checkbox"/> F. Incomplete, Resubmit

Engineer's Representative Comments:

Follow manufacturer recommendation of Cormix H2O Stop for : storage , Dosing in silo and pouring at site.

<p>Engineer's Representative : Signature & Date</p> <p><i>19-08-2024</i></p> 	<p>Received By Contractor : Signature & Date</p>
---	---

The Engineer's Representative review, comments and approval to the submitted material is for general conformance with the design concept and specifications and shall not relieve the Contractor from responsibility for any deviations from, or errors or omissions in respect of the requirements of the Contract Documents, unless the Contractor has informed the Engineer in writing of specific deviations and the Engineer has given written approval thereto.

بن غاطي BINGHATTI	<h2 style="margin: 0;">Materials Submittal Form</h2>	SILVER STONE <small>ENGINEERING CONSULTANTS</small>	
------------------------------------	--	---	--

Project Name:	Binghatti HeadQuarters		
Project Proposed:	4B + G + M + 3F + RF	Client:	BINGHATTI Developers
Project Location:	Sheikh Zayed Rd - Al Manara - Dubai	Engineering Consultant:	Silverstone Eng'g Consultants
Project Plot No.:	3630827	Main Contractor:	Granada Europe Const. Co.

MSF Reference No.:	SS-MSF-B.HQ-STR-019	MSF Date:	08-08-2024	MSF Rev.:	00
--------------------	---------------------	-----------	------------	-----------	----

Engineering Consultant has fourteen (14) working days to respond after the document has been submitted.

MSF SCOPE OF WORK				
<input type="checkbox"/> ARCH	<input checked="" type="checkbox"/> STR	<input type="checkbox"/> MEP	<input type="checkbox"/> ID/ED	<input type="checkbox"/> AI

MSF SUBMITTALS INFORMATION:				
SPECS. Ref. No.	Description	Pages	Discipline	Remarks
	Material Date sheet for waterproofing admixture by crystallization - Cormix H ₂ OStop Crystallized	2	Structure	

MAIN CONTRACTOR CONFIRMATION					
<input type="checkbox"/> Joinery/ Aluminum Head		<input type="checkbox"/> MEP Head		<input checked="" type="checkbox"/> Project Manager	
				Mohamed Rashed	
Signature:	Date:	Signature:	Date:	Signature:	Date: 08-08-2024




The Contractor strictly confirms herewith that the MSF has been studied carefully & coordinated precisely as per the approval of all drawings from the authorities and approved specifications from the engineering consultant, enclosed with contractor comments (if required).

MSF ATTACHEMENT			
<input checked="" type="checkbox"/> Drawings	<input type="checkbox"/> Catalogues	<input type="checkbox"/> Samples	<input checked="" type="checkbox"/> Other:

QA/QC ENGINEERS COMMENTS AND ACKNOWLEDGMENT	
<input checked="" type="checkbox"/> CIVIL	<input type="checkbox"/> MEP

ENGINEERING COSULTANT COMMENTS AND APPROVAL STATUS									
<input type="checkbox"/> Approved (A)			<input checked="" type="checkbox"/> Approved as Noted (B)				<input type="checkbox"/> Re- Submit (C)		
<div style="color: red; font-size: small;"> <p>- No objection on the proposed material subject to full compliance with the manufacturer recomendations for application.</p> <p>- The dosage of material to be as per the approved concrete mix design.</p> </div>									
<input checked="" type="checkbox"/> ARCH		<input type="checkbox"/> STR		<input type="checkbox"/> MEP		<input type="checkbox"/> ID/ED		<input type="checkbox"/> AI	
		Mohammad Hassan							
Signature:	Date:	Signature:	Date:	Signature:	Date:	Signature:	Date:	Signature:	Date:
			09/08/2024						

Ahmad Odeh

 <p>انوفيتيف للاستشارات استشاريون في العمارة والهندسة INNOVATIVE CONSULTANTS CONSULTING ARCHITECTS & ENGINEERS Tel.: +9714-2500173 / E-mail: iecon@iecon.ae / P.O.BOX: 7856</p>	<p>PROPOSED COMM. & RESD. BUILDING (G+3P+1st+13typ+15th) FOR: MR. MOHAMED SALEH AHMAD Plot No.: (134-1549) @ AL MAMZAR, DUBAI, U.A.E.</p>	 <p>الجنح الذهبي للمقاولات ش.ذ.م.م. OLDEN WING CONTRACTING LLC</p>
<p>MATERIAL APPROVAL SUBMITTAL IC-2024-03-MA- 15/R1</p>		
<p>To: M/s. INNOVATIVE Consultants:</p> <p>Please find attached the following Material Submittal for your approval/comments:</p>		
<p>Discipline: <input checked="" type="checkbox"/> Civil/Structural <input type="checkbox"/> Architectural <input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Plumbing <input type="checkbox"/> Others</p>		
Material Details:		List of Enclosures:
Item Description	Ready Mix Concrete - Mix Design	<input type="checkbox"/> Vendor's Technical Literature
Specs Reference		<input type="checkbox"/> Compliance Statement
BOQ Reference		<input type="checkbox"/> Comparison Sheets
Drg. Reference		<input type="checkbox"/> Previous Test Results
Material Specified		<input type="checkbox"/> Copy of the Related Specs & Other Contract Documents
Material Proposed	Ready Mix Concrete - Mix Design	<input type="checkbox"/> Samples
Manufacturer/ Local Supplier	S.S Lootah Ready Mix Concrete LLC, P.O Box 553, Dubai, UAE, Tel No. 04-3470080	<input type="checkbox"/> List of Projects Done <input type="checkbox"/> Others
		
<p>Submitted by: Eng. Danish Parwez Signature: <i>[Signature]</i> Date: 15.07.2024</p>		
<p>INNOVATIVE CONSULTANTS COMMENTS:</p> <p><input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Not Approved, Resubmit</p> <p>Comments:</p> <p style="color: blue;"> • No objection for the mix designs subject to satisfactory test results by an approved third party testing laboratory for the trial mix cubes. • Number of cubes to be taken as following: - For vertical element: 6 cubes every 10 m³ (3 for 7 days & 3 for 28 days). - For slab & beams: 6 cubes every 50 m³ (3 for 7 days, 3 for 28 days). - For mass concrete (rafts): 6 cubes every 100 m³ (3 for 7 days & 3 for 28 days). • All cubes must be tested at third party laboratory approved by the Engineer. • All reports must be submitted for Engineer approval. </p> <p>Checked by: <i>Rami Zarak</i> Signature: <i>[Signature]</i> Date: 16/07/2024 Confirmed by: Signature: Date:</p>		
<p><small>Note: INNOVATIVE Comments shall not be considered as a reason of claim of any type unless it is issued via E.I. The contractor should seek an E.I. if he considers that INNOVATIVE comments contain financial or time impact.</small></p>		

• Curing must be done as per project specs. • strictly, No chemicals / water are allowed to be added at site.
 • Maximum allowed time for any concrete truck at ~~site~~ site is 2 hrs from time of batching subject to satisfactory slump test.

MATERIAL APPROVAL REQUEST FORM (MARF)

MPL-P275 → MARF00240625-CN-B10 WITH COMMENTS

DATE SUBMITTED: 24/06/2024	PLOT NO & LOCATION: PLOT NO 3323875, LA MER – LMSC 12, JUMEIRAH FIRST, DUBAI-EAE	PROJECT: PRIVATE B+G+1+R VILLA	REFERENCE NO. MAR-STR-010
MAIN CONTRACTOR : ONYX GENERAL CONTRACTING L.L.C		SUB-CONTRACTOR :	REVISION NO. 00

REQUEST APPROVAL FOR:

STRUCTURAL / CIVIL ☐ ARCHITECTURAL ☐ MEP ☐ HVAC ☐ GLASS & ALUMINIUM ☐ FINISHES ☐

MATERIAL DESCRIPTION:

**MATERIAL SUBMITTAL FOR CRYSTALLINE WATERPROOFING CONCRETE
ADMIXTURES & REPAIR SYSTEM**

LOCATION TO BE USED:

WATER STOPPER WORKS

NO.	MATERIALS	MANUFACTURER NAME/ORIGIN	SUPPLIER NAME	APPLICATOR
1	CRYSTALLINE WATERPROOFING CONCRETE ADMIXTURES & REPAIR SYSTEM	CORMIX	GALAXY SPECIALISED	ONYX

Attachment to this submittal:



* Brochure/Catalogue	<input type="checkbox"/>	* Technical Data	<input type="checkbox"/>
* Sample	<input type="checkbox"/>	* Previous Test Certificate	<input type="checkbox"/>
* Manufacturer's Guarantee	<input type="checkbox"/>	* Alternative Proposal	<input type="checkbox"/>
* Method Statement	<input type="checkbox"/>	* Compliance Certificate	<input type="checkbox"/>
* Pre-qualification Documents	<input type="checkbox"/>	* Manufacturer's License/others	<input type="checkbox"/>

We certify that the materials submitted herewith have been reviewed in detail and are in strict conformance with the contract drawings and specifications except as otherwise stated.

Check and Verified by Main Contractor: (Hardcopy 3set with attached label sample)

CONSULTANTS COMMENTS

1. No objection for the proposed subcontractor for Crystalline Waterproofing works, subject to full compliance with project specification and local authority requirements/regulations, etc.
2. 25 years guarantee certificate to be provided as per contract.
3. Leakage test to be done.
4. Application and storage shall be as per the manufacturer's instruction/recommendation.
5. Subject to mock-up sample for final approval.
6. Dubai Trade license should be valid during project construction period.
7. Final approval subject to quality of work, performance at site, T&C. Not limited to above comments.

APPROVED WITH COMMENTS <input checked="" type="checkbox"/>	REVISE & RESUBMIT <input type="checkbox"/>	REJECTED <input type="checkbox"/>
Consultants Engineer Name & Signature 		Date 1.5 JUL 2024 BY: 

*Contractor to mark all relevant technical description in the literature.

*Shall not relieve contractor of his liabilities under the contract approval.

*Contractor should testify that the above submitted item have been reviewed in detail & are correct and in strict conformity with the contract drawings & specifications.

PROJECT : PROPOSED MIXED USED BUILDING (RESIDENTIAL & RETAIL)
(2B+G+2P+14+R) ON PLOT # AFMU001A , AL FURIAN, DUBAI

REF : BSC-95-MAT-CIV-017
REV : 0.00

CONTRACTOR NAME : BIN SHAFAR CONTRACTING L.L.C

Submission of MATERIAL SUBMITTAL

CIVIL

Date: 28/05/2024

Submitted For *

Code

APPROVAL

1

YOUR INFORMATION

2

REF:

Contract No.:

ACTION **

APPROVED

APPROVED AS NOTED

REVISE & RESUBMIT

REJECTED

B

C

D

EDMAC Engineering Consultants

QTY	DRWS., SPEC. OR BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	TYPE	CODE	
					Submittal	Action
1			GALAXY SPECIALISED WATERPROOFING SYSTEM - ADMIXTURE SYSTEM : CORMIX H2O STOP LIQUID ADMIXTURE CONTITE SEAL ACCI POLYCOAT RBE SPECTITE PVC WATER STOP	MS	1	
			PRODUCT NAME : CORMIX			
			Manufacturer / Supplier : M/s. GALAXY SPECIALISED WATERPROOFING CO LLC			

TYPE: ☒ MS : MATERIAL SUBMITTAL ☐ SM : SAMPLE ☐ GT : GUARANTESS ☐ MD : MAN. DATA ☐ TT : TEST RESULTS ☐ SP : SUB-PREQ
☐ CA : CALCULATION ☐ MOS : METHOD STATEMENT ☐ TF : TEMP. FACILITIES ☐ CT : CERTIFICATE ☐ MK : MOCKUPS
☐ SD : SHOP DRAWINGS ☐ OT : OTHERS

Specs. Reference:

BOQ Reference:

Location of use:

SUBSTRUCTURE - CONCRETE WORKS

Programme of Work Activity ID Ref:

Planned Start:

Programme of Work Description:

Planned Finish:

Copies :

SOFT COPY

1

HARD COPY

1

Main Contractor Statement:

We certify that the material submitted herewith has been reviewed in detail and is in compliance with the contract drawings and specifications except as otherwise stated hereabove

Authorised Name: ABDULAZIZ ABU KHAMIS

Signature:

CONSULTANT'S COMMENTS

- Main Contractor & Subcontractor shall be responsible for the submitted product.
- Must comply with BM/Trackers regulations.
- Revised Trail mix to be submitted prior commencing the works for our review & records.
- Draft Warranty to be submitted for 25 years.
- Final approval is subject to the follow the manufacturer recommendation & satisfactory trail mix certificate.

Copies To:

Project Manager :

For EDMAC Engineering Consultants

Date:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

MATERIAL SUBMITTAL SHEET (MSS)

Project No.: R-283

Package: Main Works

Project Name: Proposed Warehouses on Plot No. 3680700, Al Quoz, Industrial Area 3, Dubai

MSS No.:

MSS-STR-0061

Rev:

00

Date:

30-Mar-24

Submittal Related To:

Tick (✓) box where applicable

Architectural

Structural

MEP

Fit-out

General

Sl.No.	BOQ Ref.	Document No.	Rev	Description	Code
1		MSS-STR-0061	00	Material Submittal for Crystalline liquid admixture system (M/s Galaxy Specialised Waterproofing Co. LLC)	

(continue on second page in case items do not fit in this sheet)

Contractor's Representative:

Sign:

Name: Fadi Abdullah (Project Manager)

Date: 30-Mar-24

Sub-contractor's Representative:

Sign:

Name:

Date:

Action by Engineer/
Consultant/ Employer/
Project Manager

- A : No Objection, minor comments to be incorporated, works may proceed, resubmission not required.
- B : No Objection, comments as noted, works may proceed, resubmission required within 14 days. Failure to submit will result in status downgrade to C.
- C : Rejected, submittal is incorrect/unacceptable or incomplete to such an extent that a complete review cannot be undertaken.
- D : For information only, review/inspection not required.

Engineer's/Technical & Supervision Consultant's Comments:

No objection subject to M/s Arcan Approval

01 APR 2024

12:30pm

By: [Signature]
ARCAN PROJECT MANAGEMENT SERVICES



Sign:

Name:

Date:

Note: Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer. Notwithstanding any other provision of the Contract, the term "No Objection" when used in the context of any comments given by or on behalf of the Engineer shall have the meaning "No Objection to general principals only" and no such comments shall diminish or relieve the Contractor or subcontractor from any of his obligations or liabilities under the Contract or subcontract agreement and Statutory Requirements.

Comments by Project Manager (Arcan Project Management Services):

- Subject to full comply with Project requirements, Contract doc's spec & all relevant Arabic regulations
- Warranty letter to be provided

Sign:

Name:

Date:




DISTRIBUTION:

Employer ☐

Project Manager ☐

Engineer/ Consultant ☐

Contractor ☐

CONSULTANT		CLIENT		CONTRACTOR	
 آيكونيك للاستشارات المعمارية والهندسية ICONIC ARCHITECTURAL & ENGINEERING CONSULTANTS		MR. TALIB KHAIRALLAH MAJWAL		 OLDEN WING CONTRACTING LLC	
PROJECT DETAILS		PROPOSED COMM. & RESD. BLDG. (G+6+R) ON PLOT NO. 421-0137 @ AL WARQA 1ST, DUBAI, U.A.E.		LOCATION:	AL WARQA FIRST
MATERIAL SUBMITTAL REF NO.		17		DATE:	22.02.2024
MATERIAL SUBMITTAL					
DEPARTMENT		<input checked="" type="checkbox"/> STRUCTURAL <input type="checkbox"/> MECHANICAL	<input type="checkbox"/> ARCHITECTURAL <input type="checkbox"/> PLUMBING	<input type="checkbox"/> ELECTRICAL <input type="checkbox"/> OTHER.	
MATERIAL DETAILS		LIST OF ENCLOSURES			
ITEM DESCRIPTION	Water Proofing Work for Sub Structure	<input type="checkbox"/> VENDER TECHNICAL LITERATURE			
SPECS REFERENCE		<input type="checkbox"/> COMPLIANCE STATEMENT			
BOQ REFERENCE		<input type="checkbox"/> COMPARISON SHEETS			
DRG. REFERENCE		<input type="checkbox"/> PREVIOUS TEST RESULTS			
MATERIAL SPECIFIED		<input type="checkbox"/> COPY OF THE RELATED SPECS. & OTHER CONTRACT			
MATERIAL PROPOSED	Water Proofing Work for Sub Structure - Raft and Water Tank	<input type="checkbox"/> SAMPLE			
MANUFACTURER'S LOCAL SUPPLIER	Cormix International Ltd / Galaxy Specialized Waterproofing Co. LLC , P.O Box 113678, Dubai, U.A.E. Tel No. 55-8824150.	<input type="checkbox"/> LIST OF COMPLETED PROJECTS			
CONSULTANT'S PM/RE/PROJECT ENGINEER		NAME & SIGN		DATE:	
CONTRACTOR'S QA/QC		NAME & SIGN		DATE:	
CONTRACTOR'S PM/PE/ SITE ENGINEER		NAME & SIGN		DATE:	22.02.2024
Mhd. Shakil Ahmad / Eng. Danish Parwez					
For, ICONIC ARCHITECTURAL & ENGINEERING CONSULTANTS APPROVAL/ COMMENTS					
<input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> APPROVED AS NOTED <input type="checkbox"/> REVISE & RESUBMIT <input type="checkbox"/> REJECTED					
No objection for Using Cormix H2O stop water Proofing material by Galaxy 1) Subject to Fully Compliance with the Project's SPECS & approved Dmgs 2) Subject to Fully Compliance with authorities requirements & regulations 3) Subject to the Trial mix Satisfactory & approval 4) Renewal of Trade license & DCL Certificate 5) Subject to Quality & Performance at site 6) Concrete Temperature to not exceed the 30°C during Casting					
CONSULTANT'S PM/RE/PROJECT ENGINEER		NAME & SIGN		DATE:	28/2/2024
CONTRACTOR'S QA/QC		NAME & SIGN		DATE:	
CONTRACTOR'S PM/PE/ SITE ENGINEER		NAME & SIGN		DATE:	22.02.2024
		Mhd. Shakil Ahmad / Eng. Danish Parwez 			

Document Ref #	J214-PQ-CVL-11	Rev.00	Date: 15.01.2024	Sheet:
----------------	----------------	--------	------------------	--------

PROJECT	: G+4+R RESIDENTIAL BUILDING ON PLOT NO.1240411, AL MURAQQABAT, DUBAI U.A.E	PROJECT #: J214
CLIENT	: CAPITAL UNITED LLC	
CONSULTANT	: ENGINEERING CONSULTANTS GROUP (ECG)	
CONTRACTOR	: ZABEEL CONTRACTING CO LLC	DATE: 15.01.2024

APPLICATION FOR APPROVAL

TO : ECG	ATTN: PROJECT MANAGER
-----------------	------------------------------


CONTRACTOR'S PROPOSAL

APPLICATION FOR:	<input type="checkbox"/> DESIGN	<input type="checkbox"/> QA/QC STATEMENT (M.S)	<input type="checkbox"/> SAMPLE
APPROVAL OF:	<input type="checkbox"/> WORKING DRAWING	<input type="checkbox"/> MATERIALS	<input type="checkbox"/> TEST REPORT
	<input checked="" type="checkbox"/> PREQUALIFICATION DOC.	<input type="checkbox"/> EQUIPMENT	<input type="checkbox"/> OTHER

TITLE & DESCRIPTION: Crystalline Admixture - Cormix H2O Stop Liquid


LOCATION: Sub structure

ORIGINATED: ZABEEL CONTRACTING CO LLC	REF TO CONTRACT DOCUMENT:	
SUPPLIED BY: Galaxy Specialized Waterproofing CO LLC	BOQ ITEM NO.:	Variation No .01
INSTALLED BY: Galaxy Specialized Waterproofing CO LLC	SPEC. SECTION & CLAUSE:	
	DRAWING REF. NO.:	A-01-609

CONTRACTOR'S CONFIRMATION:	CONTRACTOR: SUSHANT KUMAR JENA	ECG RECEIVED:
<input type="checkbox"/> CONFIRMS TO SPECIFICATIONS	SIGNATURE : 	SIGNATURE :
<input type="checkbox"/> CONSIDERED TO BE EQUAL / BETTER THAN SPECIFIED	DATE : 15.01.2024	DATE :
<input type="checkbox"/> REASON FOR ALTERNATIVE		

ECG APPROVALS / COMMENTS

1- Approved as noted.	<input type="checkbox"/> APPROVED	(A)
2- Refer to engineer notes on the attached comments sheet.	<input checked="" type="checkbox"/> APPROVED AS NOTED	(AAN)
	<input type="checkbox"/> REVISE & RESUBMIT	(R&R)
	<input type="checkbox"/> REJECTED	(R)

FOR ECG	RECEIVED BY EMPLOYER REP:
NAME : For : Ahmed Zahran	NAME :
TITLE : Resident Engineer	SIGNATURE:
SIGNATURE: 	DATE :
DATE : 15-1-2024	

EMPLOYER REPRESENTATIVE APPROVAL / COMMENTS

<input type="checkbox"/> APPROVED	(A)
<input type="checkbox"/> APPROVED AS NOTED	(AAN)
<input type="checkbox"/> REVISE & RESUBMIT	(R&R)
<input type="checkbox"/> REJECTED	(R)

EMPLOYER REP:	TITLE:	SIGNATURE :	DATE:
RECEIVED BY CONTRACTOR	NAME	TITLE	DATE
SIGNATURE:			

APPROVAL VIDE THIS DOCUMENT SHALL NOT IN ANY WAY RELIEVE THE CONTRACTOR OF HIS RESPONSIBILITIES FROM THE COMPLIANCE TO THE CONTRACT CONDITIONS AND THE SPECIFICATIONS NOR ENTITLE HIM FOR ANY VARIATION CLAIM.

Project Name : G+4 Residential Building in Plot (#1240411), Al Muraqqabat - Dubai



COMMENTS SHEET

Ref : J214-PQ-CVL-11

Rev : 00

Date : 15 January 2024

ENGINEER'S COMMENTS:

No objection for the proposed supplier M/s. Galaxy Specialized Waterproofing CO LLC to carry out the crystalline admixture works , subject to the followings :

1. Comply with local authority Rules & Regulations.
2. to submit material submittal for review and approval.
3. Submit method statement for the activity.
4. Warranty letter by the supplier shall be provided.
5. Only certified trained applicator authorized by the manufacturer shall carry out the works at site.
6. The main contractor is responsible to coordinate between the subcontractor (M/s. galaxy) and concrete supplier.

Reviewed by:

For : Ahmed Zahran

Signature

Date

:

15-1-2024

Document Ref #	J214-MS-CVL-16	Rev.00	Date: 11.01.2024	Sheet:
----------------	----------------	--------	------------------	--------

PROJECT	: G+4+R RESIDENTIAL BUILDING ON PLOT NO.1240411, AL MURAQQABAT, DUBAI U.A.E	PROJECT #:	J214
CLIENT	: CAPITAL UNITED LLC		
CONSULTANT	: ENGINEERING CONSULTANTS GROUP (ECG)		
CONTRACTOR	: ZABEEL CONTRACTING CO LLC	DATE:	11.01.2024

APPLICATION FOR APPROVAL


TO: ECG	ATTN: PROJECT MANAGER
---------	-----------------------

CONTRACTOR'S PROPOSAL

APPLICATION FOR:	<input type="checkbox"/> DESIGN	<input type="checkbox"/> QA/QC STATEMENT (M.S)	<input type="checkbox"/> SAMPLE
APPROVAL OF:	<input type="checkbox"/> WORKING DRAWING	<input checked="" type="checkbox"/> MATERIALS	<input type="checkbox"/> TEST REPORT
	<input type="checkbox"/> PREQUALIFICATION DOC.	<input type="checkbox"/> EQUIPMENT	<input type="checkbox"/> OTHER


TITLE & DESCRIPTION: Crystalline Admixture (Cormix H20 Stop Liquid)

LOCATION: SUB STRUCTURE

ORIGINATED: ZABEEL CONTRACTING CO LLC	REF TO CONTRACT DOCUMENT:	
SUPPLIED BY: GALAXY SPECIALISED WATERPROOFING CO LLC	BOQ ITEM NO.:	Variation No -01
INSTALLED BY: GALAXY SPECIALISED WATERPROOFING CO LLC	SPEC. SECTION & CLAUSE:	
	DRAWING REF. NO.:	S-01-001
CONTRACTOR'S CONFIRMATION:	CONTRACTOR:	ECG RECEIVED:
<input checked="" type="checkbox"/> CONFIRMS TO SPECIFICATIONS		
<input type="checkbox"/> CONSIDERED TO BE EQUAL / BETTER THAN SPECIFIED	SIGNATURE :	SIGNATURE :
<input type="checkbox"/> REASON FOR ALTERNATIVE	DATE : 11.01.2024	DATE :

ECG APPROVALS / COMMENTS

1- Approved as noted.	<input type="checkbox"/> APPROVED (A)
2- Refer to engineer notes on the attached comments sheet.	<input checked="" type="checkbox"/> APPROVED AS NOTED (AAN)
	<input type="checkbox"/> REVISE & RESUBMIT (R&R)
	<input type="checkbox"/> REJECTED (R)

FOR ECG	RECEIVED BY EMPLOYER REP:
NAME : For : Ahmed Zahran	NAME :
TITLE : Resident Engineer	SIGNATURE:
SIGNATURE: 	DATE :
DATE : 15-1-2024	

EMPLOYER REPRESENTATIVE APPROVAL / COMMENTS

<input type="checkbox"/> APPROVED (A)
<input type="checkbox"/> APPROVED AS NOTED (AAN)
<input type="checkbox"/> REVISE & RESUBMIT (R&R)
<input type="checkbox"/> REJECTED (R)

EMPLOYER REP:	TITLE:	SIGNATURE :	DATE:
RECEIVED BY CONTRACTOR	NAME	TITLE	DATE
SIGNATURE:			

APPROVAL VIDE THIS DOCUMENT SHALL NOT IN ANY WAY RELIEVE THE CONTRACTOR OF HIS RESPONSIBILITIES FROM THE COMPLIANCE TO THE CONTRACT CONDITIONS AND THE SPECIFICATIONS NOR ENTITLE HIM FOR ANY VARIATION CLAIM.

Project Name : G+4 Residential Building in Plot (#1240411), Al Muraqqabat - Dubai



TRD. LIC. NO. 218847

ZABEEL
CONTRACTING



COMMENTS SHEET

Ref : J214-MS-CVL-16

Rev : 00

Date : 11 January 2024

ENGINEER'S COMMENTS:

No objection for the proposed material Crystalline Admixture (Cormix H20 Stop Liquid) supplied and installed by M/s. Galaxy Specialized Waterproofing CO LLC, subject to the followings :

1. Comply with local authority Rules & Regulations.
2. Submit method statement for the activity.
3. Only certified trained applicator authorized by the manufacturer shall carry out the works at site.
4. Contractor to strictly follow manufacture recommendation for storage and application.
5. MIR to be submitted upon delivery of the materials at site for Engineer's approval.
6. Stage wise inspection request shall be submitted for ECG review and approval.
7. After installation completion manufacturer shall inspect the work and certify.
8. sub-contractor shall provide clearance letter to be attached with steel IR once the work is done at site and inspected.

Reviewed by:


For : Ahmed Zahran





Signature



Date

:




15-1-2024


	JB1 VILLA (MV68 & MV69), JUMEIRAH BAY, DUBAI, UNITED ARAB EMIRATES	
MATERIAL APPROVAL SUBMITTAL		
Contract No.: AE_DXB_JB1_MJAFAR_VILLA		Work Package: MAIN WORKS
MAS Ref. No. JBI-C-PG-KEN-MAS-STR-RH-018		Date : 17-Nov-23
Rev. No. 01		Sample tag Ref. No.
Discipline : <input type="checkbox"/> Architectural <input checked="" type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> Plumbing <input type="checkbox"/> Fire Protection. <input type="checkbox"/> Others.		
Material Details		
Item Description : CONCRETE MIX DESIGNS		BOQ Item No. : SECTION C, CONCRETE WORKS
Name of Material : C50 WITH CRYSTALLIZATION (H2O STOP)		Reference Spec. Clause: INCLUDED IN SECTION C
Location of intended use : SUBSTRUCTURE WATER TANK WALLS, POOLS, WATER FEATURE, BASEMENT WALLS & RAFT		Drawing Ref. : INCLUDED IN DWGS FROM ST-100 TO ST-702
Manufacturer / Local Supplier : READY MIX BETON		Country of Origin : UAE
Reason for Submittal : <input checked="" type="checkbox"/> For Approval <input type="checkbox"/> For Information <input type="checkbox"/> Others ()		
Remarks : <input type="checkbox"/> As per Original <input type="checkbox"/> Alternative COMPLY TO DM 225 CIRCULAR AND AS PER APPROVED SET		
Attachments : <input type="checkbox"/> Drawing <input type="checkbox"/> Spec. <input type="checkbox"/> Sample <input type="checkbox"/> Catalog		
For Contractor		
Prepared by Material Engineer : YOUSSEF MOURAD Signature:   Date: 17-NOV-2023		
Checked/Approved by QA Manager : _____ Signature: _____ Date: _____		
Engineer's Review & Comments :		
1. Contractor shall arrange the schedule of the Trial Mix Design at the Concrete Batching Plant at the earliest with the Engineer. 2. Refer Notes in the attached Notes Sheet.		
Returned to Contractor with Status :		
<input type="checkbox"/> A : Approved <input checked="" type="checkbox"/> B: Approved as noted <input type="checkbox"/> C: Revise / Resubmit <input type="checkbox"/> D: Information		
For Engineer		Receipt Acknowledged by: Contractor
Name & Signature  Royce Agabas Date : 29-Nov-2023		Name & Signature: _____ Date: _____
For: Client's Approval		
Name & Signature : _____ Date : _____		
Distribution : <input checked="" type="checkbox"/> Employer <input checked="" type="checkbox"/> Project Manager <input checked="" type="checkbox"/> Consultant <input checked="" type="checkbox"/> Arch. Sub Consultant <input checked="" type="checkbox"/> Others ()		
The Architect/Engineer's review of this drawing/document is for the purpose of ascertaining conformity with the basic concept, profiles and general arrangements only. The review shall not be construed to mean that the Architect/Engineer accepts the detail design in the drawing, responsibility for which will remain with the Contractor. The contractor is responsible for any errors or omissions on the drawing and for meeting the requirements of the Contract documents.		

		
Client	Consultant	Main Contractor
PREQUALIFICATION SUBMITTAL		
PROJECT : PROPOSED RESIDENTIAL BUILDING (B+G+4+ROOF) PNO & LOCATION : JVC11RMRP004/JVC CLIENT : IMAN GROUP LIMITED CONSULTANT : EMSQUARE ENGINEERING CONSULTANTS		
No: CJ/165/CVL/PQ/07 Rev: 0 Date: 24/05/2023		
WE ARE SUBMITTING HERewith DOCUMENTS FOR REVIEW & APPROVAL		
Technical Submission	Architecture <input type="checkbox"/> HVAC <input type="checkbox"/>	Structure <input type="checkbox"/> FF, FA & EL <input type="checkbox"/>
	Electrical (HV / LV) <input type="checkbox"/> Specialist Works <input type="checkbox"/>	Plumbing & Drainage <input type="checkbox"/> Specialist Works <input checked="" type="checkbox"/>
Drawing Ref:		
BOQ & Specs Ref:		
Prequalification Description: PREQUALIFICATION OF WATERPROOFING SUPPLIER FOR SUBSTRUCTURE WATERPROOFING		
Prequalification Details: WATERPROOFING WORK SUPPLIER - GALAXY SPECIALISED WATERPROOFING CO LLC		
Enclosures: Attached		
Submitted By: P.O Box: 79102 Main Contractor: Dubai - UAE	Conformity By: MEP Contractor:	Conformity By: Specialist Contractor:
		Received By: Consultant
CONSULTANT COMMENTS:		
<p>①. No objection to use the waterproofing material (Core Mix H₂O stop) subject to the compliance with project specifications & authority regulations and Satisfactory → (Trial Mix Test results)</p> <p>②. Approval of Material will be given after 28 days Test results of Trial Mix.</p> <p>③. Trade license / DCL certification to be submitted upon expiry.</p> <p>④. Approval shall be null/void in case of unsatisfactory site performance.</p>		
Consultant Recommendation	Approved <input checked="" type="checkbox"/> Approved With Comments <input checked="" type="checkbox"/> Revise & Re-Submit <input type="checkbox"/> Rejected <input type="checkbox"/> For Discussion <input type="checkbox"/>	
Client Recommendation	Approved <input type="checkbox"/> Approved With Comments <input type="checkbox"/> Revise & Re-Submit <input type="checkbox"/> Rejected <input type="checkbox"/> For Discussion <input type="checkbox"/>	
Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings, specifications & authority norms & regulations. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all design details & specifications, authority norms & regulations, method statement, shop-drawings & design approvals, manufacturer recommendations, fabrication process and techniques of construction along with coordinating work with other trades, and executing the works in a safe and satisfactory manner.		
FOR EMSQUARE ENGINEERING CONSULTANT		FOR (Client *****)
QC ENGINEER - CIVIL Sign & Date:	QC ENGINEER - MEP Sign & Date:	PROJECT ENGINEER - MEP Sign & Date:
RESIDENT ENGINEER - CIVIL Sign & Date:	RESIDENT ENGINEER - MEP Sign & Date:	PROJECT ENGINEER - CIVIL Sign & Date:
PROJECT MANAGER - MEP Sign & Date:		PROJECT MANAGER - CIVIL Sign & Date:
Additional Comments / Information: <div style="font-size: 2em; margin-top: 20px;">  25/5/2023 </div>		

IMAN		 EMSQUARE ENGINEERING CONSULTANT ARCHITECTS & CIVIL ENGINEERS OFFICE: 20400401, SUITE 204, JVC, DUBAI, U.A.E.		 C.J. TEC CONTRACTING (L.L.C) شركة جي.تي.ك. للتقانات (ش.م.ع.)				
Client		Consultant		Main Contractor				
MATERIAL & SAMPLE APPROVAL SUBMITTAL								
PROJECT :		PROPOSED RESIDENTIAL BUILDING (B+G+4+ROOF)						
PNO & LOCATION :		JVC11RMRP004/JVC		No: CJ/MS/165/05 Rev: 0 Date: 24/02/2023				
CLIENT :		IMAN GROUP LIMITED						
CONSULTANT :		EMSQUARE ENGINEERING CONSULTANTS						
WE ARE SUBMITTING HERewith THE MATERIALS & SAMPLES FOR REVIEW & APPROVAL								
Technical Submission	Architecture	<input type="checkbox"/>	Structure	<input type="checkbox"/>	Electrical (HV / LV)	<input type="checkbox"/>	Plumbing & Drainage	<input type="checkbox"/>
	HVAC	<input type="checkbox"/>	FF. FA & EL	<input type="checkbox"/>	Specialist Works	<input type="checkbox"/>	Specialist Works	<input checked="" type="checkbox"/>
Drawing Ref:						⑦. C.J.Tec to send Confirmation letter after verifying the Core Mix addition into the Mix. (Core mix H ₂ O stop liquid)		
BOQ & Specs Ref:								
Material Details: CORMIX H ₂ O STOP LIQUID (For Substructure waterproofing)								
Manufacturer Details: CORMIX								
Enclosures: Attached Box: 79102 Dubai, U.A.E.								
Submitted By: Main Contractor		Conformity By: MEP Contractor		Conformity By: Specialist Contractor		Received By: Consultant		
CONSULTANT COMMENTS:								
①. DCL certificate for the material is acknowledged (Ref # CL19020718 valid until 10/11/2023). ②. Material is complying as per the DCL Scope Certification. ③. Trial Mix results have been								
CLIENT COMMENTS:								
④. C.J.Tec Undertaking letter (Ref: CJ/165/6040/2023) has been Noted. ⑤. Main contractor to verify the "Mixing of water proofing liquid" into the Concrete at the plant.								
Consultant Recommendation		Approved	Approved With Comments <input checked="" type="checkbox"/>	Revise & Re-Submit	Rejected	For Discussion		
Client Recommendation		Approved	Approved With Comments	Revise & Re-Submit	Rejected	For Discussion		
Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings, specifications & authority norms & regulations. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all design details & specifications, authority norms & regulations, method statement, shop-drawings & design approvals, manufacturer recommendations, fabrication process and techniques of construction along with coordinating work with other trades, and executing the works in a safe and satisfactory manner.								
FOR EMSQUARE ENGINEERING CONSULTANT				FOR (Client *****)				
QC ENGINEER - CIVIL Sign & Date:		QC ENGINEER - MEP Sign & Date:		PROJECT ENGINEER - MEP Sign & Date:		PROJECT ENGINEER - CIVIL Sign & Date:		
RESIDENT ENGINEER - CIVIL Sign & Date: <input checked="" type="checkbox"/>		RESIDENT ENGINEER - MEP Sign & Date:		PROJECT MANAGER - MEP Sign & Date:		PROJECT MANAGER - CIVIL Sign & Date:		
Additional Comments / Information:								

⑥. Delivery Note to be checked on delivery.

Project	PROPOSED B+G+5+R RESIDENTIAL BUILDING ON PLOT NO. JVC11WMP004 AT JVC, DUBAI,					
DOCUMENT SUBMITTAL						
Submittal No.	17	Rev	00	<input checked="" type="checkbox"/> New submittal <input type="checkbox"/> Re-submittal	Date	11-08-2022
SubContractor	M/s Galaxy Specialised Waterproofing Co. L.L.C					
Discipline	Architectural	Structural	Electrical	Mechanical	Other	
		✓				
Document Details						
Sr.	Document Ref	Rev	Document Title			
1			Method of statement (water proofing works)			
Your are kindly requested to review and to comment the above listed Document (s)						
QA/QC	Name	Signature	Project Manager	Name	Signature	
	VISHNUSAGAR			Anish Herbert		
Received by Consultant						
Name	Signature		Date			
Document Ref	Comments		Status			
Approved As Noted:						
1- Contractor and sub-Contractor to comply with Engineer comments on material / prequalification submission comments.						
2- Contractor and sub-Contractor to coordinate properly to achieve the required technical issues and to achieve max quality level.						
3- Contractor and sub-Contractors requested to comply with authority requirements.						
4- Final approval is subject to trial mix approval.						
5- Final approval is subject to performance at site.						
Approved		Approved With Comments		Revise & Resubmit		
Name		Signature		Date		
Commented by						
QA/QC						
Project Manager		A. El Seidy		12/08/2022		
Received Back By the contractor						

The Engineer : م. د. بهاتيا و اخوان M. D. BHATIA & BROS. P.O. Box 430, Tel. 4300000, Fax 4300000, Dubai, U.A.E.	The Employer : Prakash Kumar Prantal Doshi	The Contractor :  Al Maeraj CONTRACTING
Date : Jun 29, 2022	Project : B+G+1+1R Villa	Community : Dubai Hills
Project code : MDB / J - 1529	Parcel Id : 6317012	

SUB-CONTRACTOR APPROVAL FORM



Trade :	<input type="checkbox"/> (AR) Architectural	<input type="checkbox"/> (CS) Civil / Structural	<input type="checkbox"/> (ME) Mechanical
<input checked="" type="checkbox"/> (WP) Waterproofing Works	<input type="checkbox"/> (PD) Plumbing / Drainage	<input type="checkbox"/> (FF) Fire Fighting Works	
<input type="checkbox"/> (AL) Aluminium Works	<input type="checkbox"/> (E) Electrical	<input type="checkbox"/> (O) Others (Specify) :	

Description of Works to be sub-contracted	Sub structure water proofing		
Name of sub-contractor, address and contact details	Galaxy Specialised Waterproofing Co. LLC		
Contact Person*	Kapil Arora	Designation*	Managing director

Dear Sir,

Please find attached supporting documents in respect to our proposed sub-contractor for the above works

1) Prequalification	<input checked="" type="checkbox"/>
2) List of Projects	<input checked="" type="checkbox"/>
3) Full list of names, qualifications and experience of staff	<input type="checkbox"/>
4) Work Methodology	<input checked="" type="checkbox"/>
5) Written confirmation that proposed Sub-contractor will act and comply in full conformity with the Contract and the main Contractor's construction programme	<input type="checkbox"/>
6) Certificates / Licences from the relevant Authorities	<input checked="" type="checkbox"/>
7) Others (Specify) :	<input type="checkbox"/>

 CONTRACTOR'S STAMP & SIGNATURE	RECEIVED 29 JUN 2022  RECEIVED BY CONSULTANT:
Contractor's Statement: We as a Contractor certify that the items submitted herewith have been reviewed in detail and are in strict Conformance with the Contract Documents except as otherwise stated here above.	

FOR CLIENT USE:
<input type="checkbox"/> APPROVED <input type="checkbox"/> APPROVED WITH COMMENTS <input type="checkbox"/> NOT APPROVED
Comments:
AUTHORIZED BY:
SIGNATURE / DATE:

FOR CONSULTANT USE:
<input type="checkbox"/> APPROVED <input type="checkbox"/> INCORPORATE COMMENTS, REVISE & RESUBMIT <input checked="" type="checkbox"/> APPROVED WITH COMMENTS <input type="checkbox"/> NOT APPROVED
Comments:
1) Main contractor & sub-contractor will be fully responsible for the performance of product 2) Min 20 yrs of warranty certificate to be submitted after successful completion 3) There will be no any positive variation or extension of time claim will be accepted about this matter
AUTHORIZED BY:
SIGNATURE / DATE:

FORM ESTABLISHED: 01-10-2008

Notes:

1. Materials proposed must be recommended for approval.

2. Consultants or engineering made reliance in submitted during this review do not release the Contractor from compliance with the requirements of drawings and specifications. This review is only for review of general conformance with design concept of the project and general compliance with the information given in the Contract Documents. The Contractor is responsible for monitoring and controlling all quantities and dimensions, commencing the work with this approval and performing his work in full compliance with the contract documents.

- 4) In case, clients holds the right for -ve variation
- 5) Use of product on site only will be allowed after satisfactory trial mix Results
- 6) Contractor to submit trial mix reports for consultant approval
- 7) Sub-contractor to assist & take all responsibility in every stage of waterproofing
- V. Mahajan . 2106122*



MATERIAL APPROVAL REQUEST (MAR)

Project Name : **MAJAN RESIDENTIAL BUILDING - WADI AL SAFA-3 DUBAI** Ref.No. ODC/SIT/P03/MAT/056 R00 REV. 0
Project No. : **P03** Date Request **26-06-2022**

Submittal Contents:

☐ - Material/Sample ☐ - Catalogue/Brochure ☐ - Mock-up ☒ - others Technical Submittals

Description of Material / Equipment:

TECHNICAL SUBMITTAL FOR:

1 PRE- QUALIFICATION M/S. GALAXY (WATERPROOFING)

SOFT COPY

Manufacturer / Supplier Details:

a.) Local Supplier / Agent: Company Name : **GALAXY SPECIALISED WATERPROOFING** b.) Manufacturer : Company Name :
Address / Contacts : **DUBAI** Address / Contacts :
00971-558824150
☐ - Locally Manufactured ☐ - Imported c.) Country of Origin: **UAE**

Discipline

☐ - Civil / Structural ☐ - Architectural ☐ - Electrical ☐ - Mechanical
☐ - HVAC ☒ - Others

1. Project Engineer:

ENG. .

Name / Sign / Date

2. Project Manager

ENGR. SALIH ALI SALIH

Name / Sign / Date

26-06-2022



CONSULTANT COMMENTS

No objection for the proposal Submittals.
Warranty to be provide for the work

STATUS

☐ Code A : APPROVED ☒ Code B1 - APPROVED as Noted ☐ Code C : NOT APPROVED

CONSULTANT SIGN-OFF

1. Engineer:

Mathew

Name / Sign / Date

2. Project Manager/Resident Engineer

Name / Sign / Date



Villa For Mr.Satish Sanpal and Mrs. Tabinda Manzoor

REQUEST FOR MATERIAL/SAMPLE APPROVAL
Doc No. CC-EDM-MS-CIVIL-013

REV.01

Proposed B+G+1 Residential Villa on Plot No. 631-10676, For Mr. Satish Sanpal and Mrs. Tabinda Manzoor at Hadaeq Sheikh Mohammed Bin Rashid, Dubai Hills - Dubai, U.A.E.

Date: 20.05.2022

CONTRACTOR: M/s. Chirag Contracting L.L.C

Submitted For *

Code

APPROVAL

1

YOUR INFORMATION

2

CLIENT: Mr.Satish Sanpal and Mrs. Tabinda Manzoor

Contract No.:

ACTION **

APPROVED

A

APPROVED AS NOTED

B

REVISE & RESUBMIT

C

REJECTED

D

WE ARE SENDING HEREWITH / UNDER SEPARATE COVER, THE DRAWINGS/ DOCUMENTS / SAMPLES LISTED BELOW. (DELETE AS NECESSARY)

QTY	DRWS., SPEC. OR	DESCRIPTION	TYPE	CODE	
				Submittal No.	Action
1	Material/Drawing/Item name	Cormix H2O Stop Liquid Crystalline Admixture			
2	Description	Cormix H2O Stop Liquid Crystalline Admixture			
3	Manufacturer	Cormix International Limited			
4	Local Supplier	Galaxy Specialised Waterproofing Co. L.L.C			
5	Sub-contractor	Galaxy Specialised Waterproofing Co. L.L.C			
6	Location/use of material				

TYPE ☒ MS : MATERIAL SUBMITTAL ☐ SM : SAMPLE

☐ CA : CALCULATION

☐ SD : SHOP DRAWINGS

☐ MOS : METHOD STATEMENT

☐ OT : OTHERS

☒ GT : GUARANTESS ☒ MD : MAN. DATA

☐ TF : TEMP. FACILITY ☒ CT : CERTIFICATE

☒ TT : TEST RESULTS

☐ MK : MODEL

☐ SP : SUB-PREQ

Programme of Work Activity ID Ref:

Programme of Work Description:

Copies

جراغ للمقاولات (ش.ذ.م.م)
CHIRAG CONTRACTING (L.L.C)
P.O. Box : 31537, DUBAI - U.A.E.

Planned Start

Planned Finish

2:40pm

For Contractor Mr.Ahmed Magzoub (PM)

CONSULTANT'S COMMENTS

No objection to proceed.

Copies To:

Project Manager :

For EDMAC Engineering Consultants

Date:

Copies To:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.



Villa For Mr.Satish Sanpal and Mrs.
Tabinda Manzoor

REQUEST FOR SUB-CONTRACTOR PREQUALIFICATION
CC-EDM-PREQ-CIVIL-003

REV.00

Proposed B+G+1 Residential Villa on Plot No. 631-10676, For Mr. Satish Sanpal and Mrs. Tabinda Manzoor at Hadaeq Sheikh Mohammed Bin Rashid, Dubai Hills - Dubai, U.A.E.

Date: 06.05.2022

CONTRACTOR: M/s. Chirag Contracting L.L.C

Submitted For *	Code
APPROVAL	1
YOUR INFORMATION	2
ACTION **	
APPROVED	A
APPROVED AS NOTED	B
REVISE & RESUBMIT	C
REJECTED	D

CLIENT: Mr.Satish Sanpal and Mrs. Tabinda Manzoor

Contract No.:

CONSULTANT: M/s EDMAC Engineering Consulting

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS/
DOCUMENTS / SAMPLES LISTED BELOW. (DELETE AS NECESSARY)

QTY	DRWS., SPEC. OR	DESCRIPTION	TYPE	CODE	
				Submittal No.	Action
1	Prequalification	Pre Qualification For Galaxy Specialised Waterproofing Co. L.L.C			
2	Description				
3	Manufacturer	Galaxy Specialised Waterproofing Co LLC			
4	Local Supplier	Galaxy Specialised Waterproofing Co LLC			
5	Sub-contractor				
6	Location/use of material	Waterproofing			

TYPE: ☒ MS : MATERIAL SUBMITTAL ☐ SM : SAMPLE ☐ GT : GUARANTESS ☐ MD : MAN. DATA ☐ TT : TEST RESULTS ☐ SP : SUB-PREQ
☐ CA : CALCULATION ☐ MOS : METHOD STATEMENT ☐ TF : TEMP. FACILITY ☐ CT : CERTIFICATE ☐ MK : MOCKUPS
☐ SD : SHOP DRAWINGS ☐ OT : OTHERS

Programme of Work Activity ID Ref:

Programme of Work Description:

Copies

Eng: Mr. Ahmed Magzoub
CHIRAG CONTRACTING (L.L.C)
For Contractor
P.O. Box : 31537, DUBAI - U.A.E.

Planned Start:

Planned Finish:

Date: 06.05.2022

CONSULTANT'S COMMENTS

Galaxy water proofing is accepted subject to
- Material sample submission
- Method statement
- Compliance statement

Copies To:

Resident Engineer :

For EDMAC Engineering Consultants

Date:

Copies To:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

04/05/2022

Project	DXB-186 - Residential Building (B+G+M+1F+R) on Plot No.115-0181, @ AI Sabkha, Dubai, UAE. For Ms. Hana Obied Mohamed Elheillow & Ms. Mariam Obied Mohamed Elheillow							
MATERIAL SUBMITTAL								
Submittal No.	21	Rev	00	<input checked="" type="radio"/> New submittal <input type="radio"/> Re-submittal	Date	09.04.2022		
Material Description	Water Proofing Work for Sub Structure (Basement)							
Country of Origin	UAE	Specified	Alternative	Architecture	Structure	Electrical	Mechanical	Other
Manufacturer		Local Supplier/Agent		Details				
Name	Cormix International Ltd		Galaxy Specialised Waterproofing Co. LLC					
Tel			971 55 8824150					
Fax			971 4 3201231					
PO Box			113678					
Email:			kapil@galaxysp.net					
BOQ		BS		Specs				
Drawings ref.								
Attached	Data Sheet	Sample	Catalogue	Profile	Calculations	Test Results	Other	
QA/QC	Name	Signature		Project Manager- Mond. Shakir Ahmad				
				Signature				

Received by Consultant			
Name	Signature	Date	
Consultant Comments:			
<p>* No objection to the proposed system Cormix H2O stop & Seal Acc.I.</p> <p>* Trial mix is required & revised mix design.</p> <p>* Our approval is based on the warranty for 25 years.</p>			
Approved	Approved With Comments	More Information Required	Rejected
	Name	Signature	Date
Commented by	Mariam Kassen		
QA/QC			
Project Manager			
Received Back By the contractor			

* Contractor is responsible for validity of the provided certificates.

TECHNICAL DOCUMENTS APPROVAL FORM

Ref. No. : MCM-1016-TDS-CIVIL-01-00

Date : 04 January 2022

PROJECT NAME	PROPOSED DEVELOPMENT OF RESIDENTIAL VILLA (B+G+1+R) ON PLOT NO. PJFRN050_52, AT PALM JUMEIRAH, DUBAI, U.A.E.
CLIENT	Mr. NASSER ABDULLA MOHAMMED BIN HAFEZ AL JANAHI
MAIN CONTRACTOR	MCM BUILDING CONTRACTING LLC

DOCUMENT SUBMITTED : MIX-DESIGN OF SELF COMPACTING CONCRETE WITH H2O CORMIX FOR RETAINING WALL

FORM SUBMITTED BY :

for Main Contractor

FORM RECEIVED BY :

for Consultant

DATE :

DATE :

COMMENTS: No objection Subject with All Comments as following:

- ① Subject to Full Compliance with project's specifications, Contract Documents, Authorities regulations, and Green Building Requirements.
- ② successful concrete trial Mix. Along with air content, density, durability and compressive strength test result after 7, 28 days by third party laboratory in coordination with waterproofing subcontractor.
- ③ Maintain the concrete temperature Not to exceed 32°C by ice control

Approved
✓ Approved As Noted
Approved as Noted Resubmit
Not Approved
Not Required

SUPERVISING OFFICER'S APPROVAL : *Am*
and Notify the Engineer prior any changes in Mix design.

DATE :

APPROVED BY HEAD OFFICE

DATE :

CLIENT'S APPROVAL

DATE :

APPROVAL FORM RECEIVED BY CONTRACTOR ON

DATE :

SIGNATURE :

for Main Contractor

- ④ Contractor to ensure that All of the proposed Materials fully complies with DM/Tarkhees regulations and requirements.
- ⑤ subject to Client review and approval.

PROJECT TITLE:

ROSE HILL GARDENS ESTATES LLC (G+5) RESIDENTIAL
BUILDING PLOT NO. 333-1429 AL BADA

SHOP DRAWING SUBMITTAL

ROSE HILL GARDENS
ESTATES LLC

MAKS



Ref. No: KKC-MAKS-CW-SDS-029

Rev: 1

Discipline:

CIVIL

Date: 26-Aug-21

To: M/s. MAKS ENGINEERING CONSULTANCIES

Subject: SHOP DRAWING SUBMITTAL FOR WATER PROOFING PLAN & SECTION DETAILS BY M/S GALAXY SPECIALISED WATERPROOFING CO. LLC

Document Status

☐ Uncontrolled☒ Controlled

We are sending the following items:

☐ For Information☒ For Approval☐ Architectural☒ Drawings☐ Catalogue☒ Structural☐ Documents (Specify)☐ MEP☐ Other (Specify)☐ Other

Item Ref. / No.	Description	Revision	Remarks	Copies
GSWPS-103	WATER PROOFING PLAN	1		1 COPY + CD
GSWPS-106	WATER PROOFING SECTION DETAILS	1		



Subcontractor / Supplier / Manufacturer

Company Name & Address: P.O. Box No.

Telephone No.:

Fax No.:

Email:

AREA OF APPLICATION

Submitted by

Contractor's representative

KAMAL KHAWAJA BUILDING CONTRACTING LLC

Engr. Mohamed Hawwas

Date

26-Aug-21

CONSULTANT'S COMMENTS:

No objection in principal to proceed as per detail A and B as attached.

Detail E will not be applicable as the Joint at this point is not allowed.

Comments in Rev.0 are still not fully incorporated. (Refer to comment in the drawing).

Checked by:

Signature

Date: 30-08-21

☐ A - Approved as submitted☐ B - Approved as noted incorporate & proceed☒ C - Revise & Re-submit☐ D - Rejected

Received by Contractor

Contractor's Representative

Signature

Date

Distribution:

☐ Employer☐ Consultant☐ Contractor☐ Others

Client:	Mr. Mahmood Mohammad Mohammad AlDalal	
	Mr. Ahmad Mohammad Mahmood AlDalal	
Main Consultant:	Islamic Architects Consulting Engineers	Main Contractor: 3D Construction L.L.C
Project:	Proposed 1B+Ground +3 +H.C + Roof Building	Location: Al Qonz Third , Plot No 358-7191

SUB CONTRACTOR / SUPPLIER APPROVAL

Section A: Submittal Details

Date:	23/06/2021			SUBMITTAL REF	5			Revision		
Discipline:	Architectural <input type="radio"/>	Civil <input type="radio"/>	HVAC <input type="radio"/>	Pumping <input type="radio"/>	Electrical <input type="radio"/>	Fire Fighting <input type="radio"/>	IT / Communication <input type="radio"/>	External Work / Landscape <input type="radio"/>	Interior Design <input type="radio"/>	Other <input type="radio"/>

S.r	LOCAL SUPPLIER	MATERIAL DESCRIPTION
1	GALAXY SPECIALISED WATERPROOFING CO.LLC	WATER PROOFING

Section B: Contractor anticipations about Consultant Recommendation

فهم ب : توقعات المقاول حول توصيات الاستشاري

	Yes	No	Yes	No	Yes	No
shall Resolve the query	<input type="radio"/>	<input type="radio"/>	يتم حل الإشعار	<input type="radio"/>	There will be an impact on the cost	<input type="radio"/>
A site instruction will be required	<input type="radio"/>	<input type="radio"/>	سيطلب إصدار تعليمات ميدانية	<input type="radio"/>	There will be an impact on the schedule	<input type="radio"/>
A Change order will be required	<input type="radio"/>	<input type="radio"/>	سيطلب إصدار أمر تغيير	<input type="radio"/>	If YES Expected impact on the cost	<input type="radio"/>
					If YES Expected impact on the schedule	<input type="radio"/>

On behalf of the contractor, I/We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawing and specification except as otherwise stated.


أنا/نحن على الساعرة، نشهد بأن المواد المتقدمة أعلاه، روجعت وفحصت على وجهها وخللت على نحو كامل مع رسومات ومواصفات المصممين إلا ما ذكر بخصوص عليه خلاف ذلك.

Project Manager:	Construction Manager:	QA/QC Engineer:	Submitted by:	Consultant's received Stamp & Signature
ENG. RANA HAIDAR				

Section C: Consultant Comment & Recommendation

فهم ج : ملاحظات وتوصيات الاستشاري

Proceed with Galaxy specialised company as attached
 Required technical submittal with shop drawings,
 to be submit method statement

Signed By: Eng. Hassan
 Signature: 
 Date: 27/06/21

Section C: Submittal Status








فهم ج : حالة طلب الاعتماد

A- APPROVED ☐ B- APPROVED AS NOTED ☐ C- REVISE AND RESUBMIT ☐ D- REJECTED ☐ E- FOR INFORMATION ☐ F- NOT REQUIRED ☐

For and on behalf of M/s 3D Construction L.L.C	 المعمار الاسلامي للاستشارات الهندسية Islamic Architects Consulting Engineers	Contractor's received Stamp & Signature
---	---	---

Contractors or subcontractors agree to indemnify directly the reviewer and relieve the contractor from compliance with the requirements of the contract documents.
 This check is only for review of general conformity with the design concept of the project and general compliance with information given in the contract documents.
 The consultant is responsible for confirming and certifying all quantities and dimensions including fabrication processes and techniques of construction, coordination its work with other trades, and performing its work in safe and satisfactory manner.

المتسجلين أو المصنفين المتابعة يطلب الأمانة خلال هذا التوقيع لا يضمن المقاول من الالتزام بمتطلبات ومواصفات العقد.
 هذا التحقق فقط لأغراض التوافق مع المبدأ التصميمي المقدم والإقرار بالمطابقة العامة لبيانات العقد.
 المقاول مسؤول عن تأكيد وصدق كافة الكميات والأبعاد، وكميات العمل وتصنيعه وتنفيذ العمليات والتقنيات من البناء، وانه على مطابقة لبيانات ومواصفات.

SUB-CONTRACTOR SUBMITTAL			
Project	P-1492 RESIDENTIAL VILLA B+G+1 ON PLOT NO. 3435474 AT AL WASL DUBAI		
Client	AMNA MOHAMMED AHMED KHALAF ALOTAIBA	Serial No.	PCC-MS-02-P003-27-R1
Consultant	AL AJMI ENGINEERING CONSULTANTS	Prev. No.	PCC-MS-02-P003-2
Contractor	PROJECO CONTRACTING L.L.C	Date	1/4/2021
Type:	<input checked="" type="checkbox"/> Civil <input type="checkbox"/> Architectural <input type="checkbox"/> Electrical <input type="checkbox"/> Lift <input type="checkbox"/> Survey <input type="checkbox"/> Plumbing & Drainage <input type="checkbox"/> HVAC <input type="checkbox"/> Other		
Sub-Contractor Name and details:		Trade License Nbr: 697657	
GALAXY SPECIALISED WATERPROOFING CO. LLC (697657)			
Sub-Contractor proposed for:			
CRYSTALLIZATION CONCRETE (Water Proof Concrete)			
Attachments:			
Company Profile, Valid trade License, Method Statement, Draft of Warrantee Certificate			
Contractor comments:			
as per RFI reply, we are proposing Crystallization water proof concret instead of SBS mebrane water proofing			
Submitted by Contractor:		Received by Engineer:	
Name: ANSAR		Name: MOHD. ALSAHEN	
Date: 1/04/2021		Date: 01/04/2021	
 			
Civil / MEP / MEPSE Engineer's Comments:		Date:	
Valid dubai trade license attached for reference. Valid til 04/11/2021 Complainece statement attached with relevent standards and supporting test reports .Attached Comparason sheet with KIM attached for reference,Attached Vaild DCL certificate attached Warantee should be for minimum 10 years from the date of completion of the project /sample warantee lette,Attached			
		Signature: 	
Area Manager's Comments:		Date:	
Subject to full complainace during the Concrete time as mentioned on the M. statement			
		Signature: 	
The above submittal is: <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved as noted <input type="checkbox"/> Resubmit <input type="checkbox"/> Rejected			
Supervision Dept. Manager:		Received by Contractor:	
Name: Amer H. Shehadeh		Name:	
Date: 07/04/21		Date:	
			

Approval from Consultant shall not relieve the contractor of any of his liabilities under the contract and does not supersede any contract document.

Main Contractor is to undertake these works on back to back basis with subcontractor and on own responsibility as well if subcontractor fails to perform for any defect attendance in the future.
 As-built drawings should show the system used.



Government of Sharjah
Department of Public Works
Branches Department

حكومة الشارقة
دائرة الأشغال العامة
إدارة الأفرع

20/12/2020 :Date التاريخ

DJ-577-MDAF-076 : Ref.No المرجع

Material & Devices Approval Form نموذج طلب اعتماد مواد وأجهزة			
بيانات المشروع Project Details	إشياء مدرسة مايحة الخاصة - مايحة - طوي حمدة - قطعة رقم 316	رقم الحد: Cont. No	301-818
المقاول Contractor	شركة الدرويش الإمارات	الاستشاري Consult	كبري افش مي معماريون ومهندسون

نوع المواد المطلوب اعتمادها Material Submittal Type	أعمال انشائية Structural	أعمال اليكتر ميكانيك MEP	أعمال تشطيبات Architecture
--	--------------------------	--------------------------	----------------------------

Source المصدر	Manufacturer المصنع	Reference المرجع	Material as specified by priority الوصف المادة بأولوية المراسلات
Sharjah	M/s. BASF	General	Alternative Material of KIM Admixtura
	M/s. Cornix International Ltd		MasterLife WP3760 from M/s. BASF
			H20 Stop by M/s. Cornix International Ltd

Source المصدر	Manufacturer المصنع	Reference المرجع	Proposed Material for Approval الوصف المادة المقترحة
UAE	As Above	As Above	As Above

Attachments المرفقات		Alternative Proposal البديلة			
Brochure الكتيب <input checked="" type="checkbox"/>	Source المصدر	Manufacturer المصنع	Alternative Material Name اسم المادة البديلة		
Catalogues الكتالوج <input checked="" type="checkbox"/>	UAE	As Above	As Above		
Guarantee الضمان <input type="checkbox"/>	Days أيام	Cost Impact (plus) تكلفة بالإضافة	Time Impact (plus) مدة بالإضافة	Equivalant	حالة المادة البديلة Altern. Mat. Status
(≥ 2) Samples عينات <input type="checkbox"/>		Cost Impact (minus) تكلفة بالخصم	Time Impact (minus) مدة بالخصم		
C.O.F Orig شهادة منشأ <input type="checkbox"/>	Reason سبب التغيير				
C.O.F Test شهادات اختبار <input type="checkbox"/>	Mobile متحرك	Web موقع الكتروني	FAX فاكس	TEL هاتف	Supplier المورد
Data sheet البيانات الفنية <input checked="" type="checkbox"/>	054 3422455	insuf@alsindbadgroup.com	: 06-5345997	06 5345200	M/s Al Sindbad Insulation
M.O. Statement مبررة شتند <input checked="" type="checkbox"/>	Mobile متحرك	Email بريد الكتروني	FAX فاكس	TEL هاتف	Subcontractor مقاول الباطن

Contractor المقاول (ختم/توقيع) (Stamp/Sign)	Name of applicant اسم مقدم الطلب والصفة	Name of the recipient اسم المستلم	Consultant receipt (Date/sign) استلام الاستشاري (تاريخ/توقيع)
	Eng. Fehmi Hafiz	ل. ف. ح. ح. ح.	20/12/2020

Rejected مرفوض <input type="checkbox"/>	Re-Submit إعادة تقديم <input type="checkbox"/>	For Consultant use لاستخدام الاستشاري	Approved as noted مع ملاحظات <input checked="" type="checkbox"/>	Approved معتمد <input type="checkbox"/>
1- Cormix H20 Stop shall be used only				
2- Consult "Cormix" for the optimum/maximum dosage, and submit for our approval				
3- Approval is subject to satisfactory results of trial mixes for strength, durability, workability and setting time.				
4- Usage, handling and storage must comply with manufacturer's recommendations				
Omar 22/12/2020				

For D.P.W. use only خاص بدائرة الأشغال	
Rejected مرفوض <input type="checkbox"/>	Approved معتمد <input type="checkbox"/>
توقيع مهندس الدائرة DPW Engineer sign	توقيع وختم الاستشاري Consultant sign & stamp
23/12/2020	23/12/2020
CONT. RECIEVED استلام المقاول	
Sign توقيع	
Date التاريخ	
ملاحظة: الإحتضار النهائي للمواد يكون بعد إحتضار دائرة الأشغال للمواد مع مبرر بالحدود القصوى لأي ملاحظات مادية أو زمنية من قبل المقاول	
Note: Final D.P.W. approval will be after site mock up approval without any claim by contractor for any Cost / Time impact	