

STAR WATER SYSTEMS, INC.

250 MARKET ST.
LEBANON, OR 97355
PH. 451-3298 FAX 259-3297

Well Flow Test Report

Report For: **Micah Ritschard**
6388 Old Stage Rd.
Central Point, OR 97502

Test Date: **March 8, 2023**
Well Site: **2255 Fuller Ln.**
Lebanon, OR 97355

Requested By: **Micah Ritschard**

Location of Well on Property: **In pumphouse behind house**

Well type: **Drilled** Casing size: **4"** Casing is: **5** Inches **Above** Ground
Well depth if known: **u/k** Sanitary seal: **Yes** Sanitary vent: **Yes**
Type of pump: **Submersible** HP: **1/2** Make: **Grundfos** Model: **10SQ05**
Was pump part of permanent system: **Yes**
Flow measuring equipment: **Flow meter**
Water level measuring equipment: **Electronic probe**

Samples Collected: Coliform ☐ Nitrate ☐ Arsenic ☐ Lead ☐ General ☐
Other:

Test Time	Flow Rate	Gallons Pumped	Water Level	Back Pressure	Comments
	GPM				
Start: 8:30	10	0	15	48	Clear Water
15 min.	6	150	49	58	
30 min.	6	240	49	58	
45 min.	6	330	49	58	
1 hour	6	420	49	58	
1 1/2 hours	6	600	49	58	
2 hours	6	780	49	58	
2 1/2 hours					
3 hours					
3 1/2 hours					
4 hours					

Total Gallons Pumped: **780** Recovery After: **5** Min. To: **33** Feet

Comments: **Pump started to break suction @ 8:43. Restrict flow to 6gpm**

THIS TEST DATA IS ACCURATE FOR THE DATE TAKEN. WE MAKE NO CLAIMS AS TO THE PERFORMANCE OF THIS WELL AT ANY OTHER TIME.

Data collected by: **cs**
Star Water Systems, Inc. CCB# 51054