

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 000 29260
Drilling Permit No. 889647

Water right or injection well # _____

2. OWNER: Kevin Self

Name Kevin Self

Address 588 Adit Lane

City Bannock Ferry State ID Zip 83805

3. WELL LOCATION:

Twp. 6S North ☒ or South ☐ Rge. 01 East ☒ or West ☐

Sec. 30 10 acres 1/4 NE 1/4 SW 1/4

Gov't Lot _____ County Boundary

Lat. 48° 57.228 (Deg. and Decimal minutes)

Long. -116° 23.298 (Deg. and Decimal minutes)

Address of Well Site 588 Adit Lane

City Bannock Ferry

(Give at least name of road + distance to road or landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection

☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	23 lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6 3/4	-2	117	25	Steel	☒	☐	☐	☒
					☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 117

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____

Manufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device well cap

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 80 Static water level (ft) 60

Water temp. (°F) 45 Bottom hole temp. (°F) 45

Describe access port well cap

Well test: _____ Test method: _____

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
117	30 gpm	2 hrs	☐	☐	☒	☐

Water quality test or comments: good

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	38	Seal		X
6	0	80	Large cobble gravel		X
6	80	100	Wet cobble clay	X	
6	100	102	Cobble, sand gravel	X	
6	102	117	gravel, coarse sand	X	

RECEIVED

JUL 29 2019

IDWR / NORTH

Completed Depth (Measurable): 117

Date Started: May 13-19 Date Completed: May 13-19

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Universal Drilling Co. No. 650

*Principal Driller Scott HAHG Date May 13-19

*Driller Austin HAHG Date May 13-19

*Operator II Dylan HAHG Date May 13-19

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.