

Town of Truro

New Public Works Facility

Project Inquiries & Responses

- *Explore well relocation from the DPW to Snow's Field or to abutting parcels*
 - A formal well relocation analysis was not completed and was not part of the initial scope of work
 - Historic documentation for Snow's Field was reviewed
 - Snow's Field had been showing a gradual increase in levels of 1,1,1-trichloroethane which was a concern to MADEP at the time
 - The Town would need to secure separate funding to support further investigation of this or any other potential site for a new well
 - Any evaluation of alternate locations should also take into consideration impacts and costs associated with a new pumping system, pipe conveyance system (including easements), potential treatment system, and water storage (if necessary)

