

PIN: 7694-00-9533

Permit Type: Septic Record

PIN: Map # 7694 Sheet # 00 Block # 00 Lot # 9725 9533
 Property Owner SETH ANDREW TR Permit No. APL-119 Date 4/9/09
 Property Address 536 RED BANK ROAD Sub-Division Butter Hills Sect. No.
 Property Location HWY 23174 to (L) ON Red BANK ROAD to Lot No. 10
GRAVEL - SECOND HOUSE ON (R)

Septic Tank ☒ New ☐ Existing Material Manufacturer
☒ New Nitrification Field: Square Footage 600 Type EPA Length of Lines 150 Liquid Capacity No. Units
☐ Gravity System Distribution: ☐ Serial ☐ D Box ☐ Other
☒ Pump System Tank Manufacturer Liquid Capacity Pump Manufacturer Model No.
☐ Repair Nitrification Field: Existing Square Footage Square Footage Added 5070 sq. ft.
 Existing Line Type Length No. Units New Line Type Length No. Units

SYSTEM DESIGNED FOR: NEW ☐ REPAIR ☐
 Residence ☒ No. Bedrooms 3 Mobile Home ☐ No. Bedrooms Other Establishment ☐ Type Size
 Basement: Yes ☐ No ☒ Sewer Outlet Locations FRONT First Floor ☐ Basement Level ☐ Site Classification Water Supply
 Nearest Distance to: Water Supply 65' Stream 60' Foundation 5' Property Line 10' Installed by: MARK STAPARD
 Remarks: Approved drainfield (Q12)

System being used, power on 4/9/09
Type 3b requires inspection every 5 years.

Approved Yes ☒ No ☐ Sanitarian Carol Pace

NOTICE: This approval is issued subject to all the provisions of Article II, G.S. 130A 333-343 of the General Statutes of North Carolina and Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal, 15A NCAC 18A, 1900. No person is permitted to make alterations in the design or use of this system other than its designated use without approval of an authorized sanitarian. This approval indicates that this system has been installed in compliance with the standards as set forth in the above regulation, but shall in no way be taken as a guarantee that the system will function satisfactorily for any given period of time.