

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION (Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jean McNeely DATE 10/7/77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Out E. Mombe Rd. T.R. on 1402 at Bethel Church. T.R. on 1331. House on Rt. Next Door to Red Clark. S. R. No. 1331

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☒ Mobile Home () Business () Other _____

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil Prov Suitable
Garbage Disposal Unit Yes () No (☒) Percolation Rate _____
Auto. Dishwasher Yes (☒) No () Topography slup slope
Auto. Wash. Machine Yes (☒) No () Depth to Water Table Low
Site Suitable Yes (☒) No () Rock or other impervious formations None

Lot Area 20000 sq ft



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 210

Depth of Stone in Lines 16"

Water Supply: Individual (☒)

Public ()

Installed by F. J. Erwin

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well to be more than 50' from Septic tank & lines. House not started at this time. House Foundation to be 10' from lines.

CERTIFICATE OF COMPLETION BY E. G. Stutenson DATE 10/2/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White

Inspection Dept. Copy: Yellow

Sanitarian's Copy: Pink

Owner's Copy: Gold