


WIRING DIAGRAM FOR SUSI ADAPTERS MODEL # SWDWS9-SK & SWDWL9-SK FOR SHARK/EPM 6000 METER IN WESTINGHOUSE FT-21, FT31 CASE w/POWER CONNECTED

SERVICE: WYE, 4-WIRE 3 PTs AND 3 CTs



NOTES:

1. SELECT "3 EL WYE" (3 ELEMENT WYE) IN METER PROGRAMMING SETUP.
2. CONNECT GWD DURING INSTALLATION AS DESIRED.

C	4/25/2012	MS			Added EPM 6000 & Updated Address
B	2/18/09	CM			Changed L to N
A	12/01/08	RH			INITIAL RELEASE
REV.	DATE	BY	CHK	APVD	REVISION DESCRIPTION
INFORMATION ON THIS DRAWING IS THE SOLE PROPERTY OF SUSI ADAPTERS. DO NOT COPY OR DISTRIBUTE WITHOUT WRITTEN PERMISSION FROM SUSI ADAPTERS INC. INTERPRET PER ANSI Y14.5 DO NOT SCALE DRAWING! ALL DIMENSIONS IN INCHES UNLESS NOTED OTHERWISE TOLERANCES SHALL BE: XXX = ± .005 X = ± .05 XX = ± .015 ANGLES: ± 0°5					
				 SUSI ADAPTERS Inc. 9560 Red Bird Lane Johns Creek, GA 30022 PH: 770-448-6810 www.SUSIadapters.com	
DWN: RLH				TITLE: SWDWS9-SK & SWDWL9-SK	
DATE: 11/20/08				SHARK/EPM 6000 METER WIRING	
CHK:				DWG. NO. 610-1520-04	
ENGR:				REV: C	
SHEET 0# 1				SCALE: 0.4" = 1"	
				DWG SIZE: B	