
М				Max Flow To	Pipe Size		Media	Mineral Tank		Installation			Shipping	Operating
s	Maximum Recommended Service Flow Rates			Drain	Service	Drain	Per Tank	Diameter	Height	Height	Depth	Width	Weight	Weight
U:	JSGPM	USGPM	USGPM	USGPM	in	in	ft3	in	in	in	in	in	lbs	lbs
	I/s	I/s	l/s	I/s	mm	mm	m3	mm	mm	mm	mm	mm	kg	kg
-	20	30	16	12	1"	1"	2.75	14	66	81	20	37	767	1,567
	1.26	1.89	1.01	0.76	25	25	0.08	356	1676	2057	508	940	348	711
i-	28	40	22	15	1"	1"	3.5	16	66	81	22	41	969	1,969
	1.77	2.52	1.39	0.95	25	25	0.10	406	1676	2057	559	1041	440	894
i-	34	52	26	20	1"	1"	4.5	18	68	83	24	45	1,148	2,348
	2.15	3.28	1.64	1.26	25	25	0.13	457	1727	2108	610	1143	521	1,065
.6	6-	USGPM I/s 4- 20	USGPM USGP	USGPM USGPM USGPM I/s I/s I/s 4- 20 30 16 1.26 1.89 1.01 6- 28 40 22 1.77 2.52 1.39 8- 34 52 26 2.15 3.28 1.64	USGPM USGPM USGPM USGPM I/s I/s I/s I/s 4- 20 30 16 12 1.26 1.89 1.01 0.76 6- 28 40 22 15 1.77 2.52 1.39 0.95 8- 34 52 26 20 2.15 3.28 1.64 1.26	USGPM USGPM USGPM USGPM In	USGPM USGPM USGPM USGPM in in I/s I/s I/s I/s mm mm 4- 20 30 16 12 1" 1" 1.26 1.89 1.01 0.76 25 25 6- 28 40 22 15 1" 1" 1.77 2.52 1.39 0.95 25 25 8- 34 52 26 20 1" 1" 2.15 3.28 1.64 1.26 25 25	USGPM USGPM USGPM USGPM in in ft3 1/s I/s I/s I/s mm mm m3 4- 20 30 16 12 1" 1" 2.75 1.26 1.89 1.01 0.76 25 25 0.08 6- 28 40 22 15 1" 1" 3.5 1.77 2.52 1.39 0.95 25 25 0.10 8- 34 52 26 20 1" 1" 4.5 2.15 3.28 1.64 1.26 25 25 0.13	USGPM USGPM USGPM USGPM in in ft3 in 4- 20 30 16 12 1" 1" 2.75 14 1.26 1.89 1.01 0.76 25 25 0.08 356 6- 28 40 22 15 1" 1" 3.5 16 1.77 2.52 1.39 0.95 25 25 0.10 406 8- 34 52 26 20 1" 1" 4.5 18 2.15 3.28 1.64 1.26 25 25 0.13 457	USGPM	del USGPM USGPM USGPM USGPM USGPM in in ft3 in in in 4- 1/s 1/s 1/s 1" 1" 2.75 14 66 81 1.26 1.89 1.01 0.76 25 25 0.08 356 1676 2057 6- 28 40 22 15 1" 1" 3.5 16 66 81 1.77 2.52 1.39 0.95 25 25 0.10 406 1676 2057 8- 34 52 26 20 1" 1" 4.5 18 68 83 2.15 3.28 1.64 1.26 25 25 0.13 457 1727 2108	USGPM USGPM USGPM USGPM USGPM USGPM In In In In In In In I	USGPM USGPM USGPM USGPM USGPM In In In In In In In I	USGPM

Typical service based on 10 usgpm/ft2 Peak based on 15 usgpm/ft2 Flowrates may change depending upon actual feed water quality water conditions. Backwash flowrates based on cold water. If regeneration feed water is above 450F, The backwash flow rate will have to be increased.




- DUPLEX FILTER, CALENDAR CLOCK INITIATED, MULTI-TANK SYSTEMS ARE SERIES REGENERATION.
- FILTER IS EQUIPPED WITH 1.25" VALVE ELECTRONIC BALL VALVE WITH MAIN ELECTRONIC CONTROLLER.
- MAXIMUM RECOMMENDED SYSTEM PRESSURE IS 100 PSI (690 kPa) AND MINIMUM INLET MEDIA BED CONSISTS OF NSF APPROVED, NEXTSAND ON A GRADED SUPPORT BED PRESSURE IS 40 PSI
- MAXIMUM RECOMMENDED SYSTEM TEMPERATURE IS 100 °F (38 °C).
- REQUIRES 120 VOLT, 1 PHASE, 60 Hz ELECTRICAL POWER.
- ALL EXTERNAL PIPING, FITTINGS, AND VALVES SHOWN BY BROKEN LINES ARE SUPPLIED
- MINERAL TANKS AND MEDIA ARE NSF APPROVED.
- DUE TO SLIGHT EXPANSION AND CONTRACTION OF MINERAL TANK, PIPING MUST BE DESIGNED TO ALLOW SOME MOVEMENT. AS WELL AS BE PROTECTED FROM VACUUM. FLEX CONNECTORS AND A VACUUM BREAKER MAY BE REQUIRED. FAILURE TO INSTALL EITHER OF THEM OR IMPROPERLY INSTALL THEM MAY VOID THE WARRANTY.
- AVAILABLE IN 1", 1.25", 1.5" PIPING CONNECTION.

RAW WATER REGENERATION PIPING SHOWN

- FLOOR DRAINS MUST BE SIZED TO CARRY THE MAX. LISTED FLOW TO DRAIN.
- REFER TO THE INSTALLATION AND OPERATION MANUAL FOR FURTHER DETAILS.
- USE PROPER UNION OR FLANGE FOR THE PIPE CONNECTION TO VALVE FOR EASY MAINTENANCE.
- SYSTEM MUST BE INSTALLED TO COMPLY WITH ALL FEDERAL, STATE, PROVINCIAL, & LOCAL CODES.





LEGEND:

ISOLATION VALVE

BYPASS VALVE

PRESSURE GAUGE & SAMPLE POINT

OPEN DRAIN

VACUUM BREAKER

FLEX CONNECTOR

RAW WATER LINES

FILTERED/SOFTENED WATER LINES

WATER TO OPEN DRAIN

TREATED WATER LINES

ELECTRONIC BALL VALVE

UNION OR FLANGE

95MTS NEXTSAND FILTER 1.25" DUPLEX SYSTEM

THIS DOCUMENT CONTAINS INFORMATION WHICH IS PROPRIETARY TO CANATURE WATERGROUP. THE REPRODUCTION, TRANSFER, OR OTHER EXPLOITATION OF ANY INFORMATION CONTAINED HEREIN IS NOT PERMITTED WITHOUT PRIOR WRITTEN APPROVAL OF CANATURE WATERGROUP. THE MANUFACTURER RESERVES THE RIGHT TO MAKE PRODUCT REVISIONS, WHICH MAY DEVIATE FROM THE SPECIFICATIONS AND DESCRIPTIONS STATED HEREIN WITHOUT OBLIGATION TO CHANGE PREVIOUSLY MANUFACTURED PRODUCTS OR TO NOTE THE CHANGE. NOT DRAWN TO THE SCALE UNLESS OTHERWISE SPECIFIED.

Project: Date: 02-13-2024 Rev

Dwa# 95MTS NX1.25D