



Coefficients Of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance: 20%

RCC %:	80				70				50			30			10			0
RW %:	70	50	30	0	70	50	30	0	50	30	20	50	30	20	50	30	20	0
RCR: 0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.00	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1	1.10	1.06	1.02	.98	1.07	1.03	1.00	.87	.99	.96	.94	.95	.93	.91	.92	.90	.88	.86
2	1.01	.93	.87	.82	.98	.91	.86	.75	.88	.83	.79	.85	.81	.77	.82	.78	.75	.73
3	.92	.83	.75	.69	.90	.81	.74	.64	.78	.72	.67	.75	.70	.66	.73	.69	.65	.63
4	.85	.74	.66	.59	.83	.73	.65	.56	.70	.63	.58	.68	.62	.57	.66	.61	.57	.54
5	.79	.66	.58	.52	.77	.65	.57	.49	.63	.56	.51	.61	.55	.50	.59	.54	.50	.48
6	.73	.60	.52	.45	.71	.59	.51	.44	.57	.50	.45	.56	.49	.45	.54	.49	.44	.42
7	.68	.55	.46	.41	.66	.54	.46	.39	.52	.45	.40	.51	.45	.40	.50	.44	.40	.38