




Certificate#4810.01

Report No.:
BLC1904012E-U-Y



Photometric Data



Illuminance at a Distance

	Center Beam fc	Beam Width	
17.0ft	2.92 fc	56.7 ft	49.7 ft
34.0ft	0.73 fc	113.4 ft	99.3 ft
51.0ft	0.32 fc	170.1 ft	149.0 ft
68.0ft	0.18 fc	226.8 ft	198.7 ft
85.0ft	0.12 fc	283.5 ft	248.4 ft
102.0ft	0.08 fc	340.3 ft	298.0 ft

■ Vert. Spread: 118.1°
■ Horiz. Spread: 111.2°



Laboratory: Belling Test Laboratory Co., LTD A2LA Certificate# 4810.01
Unit 401, No. 309 Xinxin Seven Road, Zengcheng District,
Guangzhou, People's Republic of China. Website: <http://www.bltest.com>

Report Format Number BL-FM-SA-012