LED Parking Garage Light Installation Instruction

Cautions:

- 1. Can not use the electric generator to test the LED lamp.
- 2. Please abide by related country, regional and local law and regulations when install this fixture.
- 3. Please turn off the power before installation or maintenance.
- 4. Proper earth grounding is required to ensure safety.


Notice:

- 1. To avoid possibility of electrical shock or fire, the installation personnel must have professional electric
- 2. Please wear gloves to avoid injury before installation.
- 3. If any smoke or spark of the wire happened, please turn off the power immediately and notify relevant

Attention:

- 1. Please check if there is any damage during shipping. If so, please contact manufacturer timely.
- 2. Please read the installation instruction carefully to check whether all the accessories are complete. After confirmation, then install the fixture according to installation steps.

Wiring Diagram:



☑Installation Method I ·

- 1. Disassemble the driver box cover by loosen the two screws on the driver box; Figure 1-1
- 2. Loosen the 3/4 plug on the driver box cover by screwdriver; Figure 1-2
- 3. Fix the driver box cover on the 3/4 tube; Figure 1-3
- 4. Insert the mounting hole of radiator horizontally to the shaft of driver cover; Figure 1-4
- 5. Connect the input line and ground; If the fixture is equipped with sensor, adjust the sensor settings, Take relevant waterproof measures after the wires are connected; Figure 1-5
- 6. Turn the radiator up then cover the driver box, Figure 1-6
- 7. Lock the two cap screws, the product is installed. Figure 1-7




Figure 1-1



Figure 1-2




Figure 1-3




☑Installation Method II:

- 1. Disassemble the driver box cover by loosen the two screws on the driver box; Figure 2-1
- 2. Loosen the 3/4 plug on the driver box cover by screwdriver; Figure 2-2
- 3. Drill the holes on the ceiling accordingly to fit the plate; Figure 2-3
- 4. Fix the driver box cover on the ceiling; Figure 2-4
- 5. Insert the mounting hole of radiator horizontally on the shaft of driver cover; Figure 2-5
- 6. Connect the input line and ground; If the fixture is equipped with sensor, adjust the sensor settings; Take relevant waterproof measures after the wires are connected; Figure 2-6
- 7. Turn the radiator up then cover the driver box, Figure 2-7 8. Lock the two cap screws, the product is installed. Figure 2-8




□Installation Method III:

- 1. Disassemble the driver box cover by loosen the two screws on the driver box; Figure 3-1
- 2. Loosen the 3/4 plug on the driver box cover by screwdriver; Figure 3-2
- 3. Drill holes on the ceiling; Figure 3-3
- 4. Fix the driver box cover on the ceiling; Figure 3-4
- 5. Fix the lower bracket on the driver box cover; Figure 3-5
- 6. Align with the holes of upper and lower bracket; tighten with screws; Figure 3-6
- 7. Insert the mounting hole of radiator horizontally on the shaft of driver cover; Figure 3-7
- 8. Use M20 waterproof connector when connecting AC wire or dimming wire, take relevant waterproof measures at both sides of inlet. Figure 3-8
- 9. Connect the input line and ground; If the fixture is equipped with sensor, adjust the sensor settings; Take relevant waterproof measures after the wires are connected; Figure 3-9
- 10. Turn the radiator up then cover the driver box, Figure 3-10
- 11. Lock the two cap screws, the product is installed. Figure 3-11



Structure of motion sensor



Setting:


By selecting the combination on the DIP switch, sensor data can be precisely set for each specific application.

	-			_		_		
			1		į	2	_	
ON	Ι		0	Ν	C	N	1	00%
1	II		0	Ν	9	-		75%
	II	I	=		C	N		50%
	IV	7	7-		5	-		25%
		I	3	-	1	5	1	
	I	(NC	0	N	10	1	5S
ON	II	Ī	-	0	N	01	1	30S

Detection area

Detection area can be reduced by selecting the combination on the DIP switches to fit precisely each application.

Factory setting: I



Hold time

Refers to the time period the lamp remains at 100% illumination after no motion detected.

Factory setting: VI

		6	7	8	
	I	ON	ON	ON	08
ON	II	-	ON	ON	58
t	III	ON	-	ON	5min
	IV	-	-	ON	10min
	V	ON	ON	-	30min
	VI	-	ON	-	1h
	VII	-	-	-	+∞

Stand-by period

Refers to the time period the lamp remains at a low light level before it completely switches off in the long absence of people. When set to Disable mode, the low light is maintained until motion is detected.


Factory setting: I

ON †		1	2	
	I	ON	ON	50%
	II	-	ON	30%
	III	ON	1	20%
	IV	-	-	10%

Stand-by dimming level

The low light level you would like to have after the hold time in the long absence of people.

Factory setting: I



Daylight sensor

The sensor can be set to only allow the lamp to illuminate below a defined ambient brightness threshold.

When set to Disable mode, the daylight sensor will switch on the lamp when motion is detected regardless of ambient light level.

100lux, 100lux, 50lux: twilight operation, 10lux, 5lux: darkness operation only. Note that daylight sensor is active only when lamp totally switches off.

Factory setting: VII

Warning / Avertissement

MIN 75°C SUPPLY CONDUCTOR

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

LES FILS D'ALIMENTATION 75°C MIN

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS.